



*Supplement of*


**A method for measuring total aerosol oxidative potential (OP) with the dithiothreitol (DTT) assay and comparisons between an urban and roadside site of water-soluble and total OP**

Dong Gao et al.


*Correspondence to:* Rodney J. Weber (rweber@eas.gatech.edu)

The copyright of individual parts of the supplement might differ from the CC BY 3.0 License.


## Supplemental Information




**Figure S1.** Map of sampling sites (Scale is 1:5000). (Map data ©2016 Google Imagery ©2016, DigitalGlobe, Sanborn, U.S. Geological Survey, USDA Farm Service Agency.)




**Figure S2.** (a)  $\text{OP}^{\text{WS-DTT}}$  ( $N=9$ ) and (b)  $\text{OP}^{\text{Total-DTT}}$  ( $N=9$ ) comparisons for PM samples collected simultaneously at GT using two HiVol sampler. Regression analysis was done by orthogonal regression. The dotted line is 1:1.




**Figure S3.** 30-minute sonication vs. 2.5-hour shaking comparison for OP<sup>WS-DTT</sup> measurements (N=7). Regression analysis was done by orthogonal regression. The dotted line is 1:1.




**Figure S4.** The relative  $\text{OP}^{\text{DTT}}$  response (the ratio of  $\text{OP}^{\text{DTT}}$  extracted by methanol-containing solvent to  $\text{OP}^{\text{DTT}}$  extracted by DI only) to adding small amount of methanol into extraction solvent.



**Figure S5.** 30-minute sonication vs. 2.5-hour shaking comparison for OP<sup>Total-DTT-3</sup> measurements (N=9). Regression analysis was done by orthogonal regression. The dotted line is 1:1.



**Figure S6.** Graphical assessment of data normality.



**Figure S7.** Blank-corrected DTT consumption rate comparison of the automated system to a manual analysis using ambient samples (N=5).

**Figure S1.** Correlation matrix for the various metals and OP<sup>DTT</sup> obtained by method 3

GT		Water-soluble						Total						Water-insoluble					
N=35		OC	EC	DTT	K	Mn	Fe	Cu	DTT	K	Mn	Fe	Cu	DTT	K	Mn	Fe	Cu	
Water-soluble	EC	<b>0.83**</b>	<b>1</b>																
	DTT	<b>0.79**</b>	<b>0.84**</b>	<b>1</b>															
	K	0.6**	<b>0.88**</b>	0.63**	<b>1</b>														
	Mn	<b>0.86**</b>	0.7**	0.46*	0.54**	<b>1</b>													
	Fe	<b>0.8**</b>	<b>0.82**</b>	0.49*	0.62**	<b>0.82**</b>	<b>1</b>												
Total	Cu	<b>0.7**</b>	<b>0.78**</b>	<b>0.77**</b>	<b>0.71**</b>	<b>0.72**</b>	0.64**	<b>1</b>											
	DTT	0.66**	<b>0.78**</b>	<b>0.71**</b>	<b>0.82**</b>	0.69**	0.48*	<b>0.76**</b>	<b>1</b>										
	K	0.67**	<b>0.84**</b>	0.53**	<b>0.82**</b>	<b>0.7**</b>	0.59**	0.52**	0.69**	<b>1</b>									
	Mn	0.67**	0.66**	0.43*	0.51**	<b>0.94**</b>	0.61**	0.65**	<b>0.73**</b>	<b>0.7**</b>	<b>1</b>								
	Fe	0.53**	0.58**	0.36	0.51**	<b>0.86**</b>	0.6**	0.62**	<b>0.71**</b>	0.56**	<b>0.97**</b>	<b>1</b>							
Water-insoluble	Cu	<b>0.72**</b>	<b>0.78**</b>	<b>0.78**</b>	0.62**	<b>0.87**</b>	0.54**	<b>0.97**</b>	<b>0.78**</b>	<b>0.7**</b>	<b>0.88**</b>	<b>0.84**</b>	<b>1</b>						
	DTT	0.44*	0.48**	-0.23	0.55**	0.57**	0.26	0.38	<b>0.87**</b>	0.50*	0.66**	0.63**	0.56**	<b>1</b>					
	K	0.6**	0.6**	0.42*	0.61**	<b>0.76**</b>	0.54**	0.3	0.66**	<b>0.94**</b>	<b>0.74**</b>	0.69**	0.61**	0.50*	<b>1</b>				
	Mn	0.43*	0.66**	0.31	0.37	<b>0.79**</b>	0.64**	0.43*	0.62**	0.62**	<b>0.96**</b>	<b>0.95**</b>	<b>0.75**</b>	0.59**	0.7**	<b>1</b>			
	Fe	0.49*	0.57**	0.35*	0.49*	<b>0.86**</b>	0.57**	0.59**	<b>0.7**</b>	0.55**	<b>0.96**</b>	<b>0.9995**</b>	<b>0.84**</b>	0.64**	0.69**	<b>0.95**</b>	<b>1</b>		
	Cu	<b>0.72**</b>	<b>0.78**</b>	<b>0.78**</b>	0.61**	<b>0.88**</b>	0.54**	<b>0.97**</b>	<b>0.78**</b>	<b>0.7**</b>	<b>0.89**</b>	0.85**	<b>0.9999**</b>	0.56**	0.63**	<b>0.76**</b>	<b>0.84**</b>	<b>1</b>	

Note: r>0.70 are bold.

\*\*p<0.01. \*p<0.05. Correlation not statistically significant is without superscript.

RS		Water-soluble						Total						Water-insoluble					
		OC	EC	DTT	K	Mn	Fe	Cu	DTT	K	Mn	Fe	Cu	DTT	K	Mn	Fe	Cu	
Water-soluble	EC	<b>0.75**</b>	<b>1</b>																
	DTT	<b>0.83**</b>	<b>0.79**</b>	<b>1</b>															
	K	<b>0.86**</b>	0.68**	0.67**	<b>1</b>														
	Mn	<b>0.79**</b>	0.63**	0.43*	0.56**	<b>1</b>													
	Fe	<b>0.8**</b>	<b>0.8**</b>	<b>0.88**</b>	0.66**	0.45*	<b>1</b>												
Total	Cu	0.64**	<b>0.78**</b>	0.54**	<b>0.77**</b>	0.36	0.63**	<b>1</b>											
	DTT	<b>0.71**</b>	0.68**	0.56**	0.6**	0.56**	0.49*	0.55**	<b>1</b>										
	K	<b>0.88**</b>	<b>0.71**</b>	0.69**	<b>0.9**</b>	0.65**	<b>0.72**</b>	0.51*	0.67**	<b>1</b>									
	Mn	<b>0.86**</b>	0.69**	0.48*	0.53**	<b>0.95**</b>	0.56**	0.56**	0.66**	0.61**	<b>1</b>								
	Fe	<b>0.79**</b>	<b>0.75**</b>	0.57**	0.55**	<b>0.72**</b>	<b>0.72**</b>	<b>0.71**</b>	0.66**	0.6**	<b>0.9**</b>	<b>1</b>							
Water-insoluble	Cu	0.66**	<b>0.72**</b>	0.4	<b>0.78**</b>	0.65**	0.56**	<b>0.93**</b>	<b>0.72**</b>	0.57**	<b>0.79**</b>	<b>0.84**</b>	<b>1</b>						
	DTT	-0.34	-0.37	-0.51**	-0.47*	-0.37	-0.40*	-0.40*	<b>0.84**</b>	-0.43*	0.31	-0.39*	0.43*	<b>1</b>					
	K	0.6**	0.47*	0.37	0.4	0.56**	<b>0.73**</b>	0.28	0.47*	<b>0.7**</b>	0.63**	0.62**	0.24*	-0.27	<b>1</b>				
	Mn	<b>0.77**</b>	<b>0.72**</b>	0.42*	0.44*	<b>0.81**</b>	0.62**	0.65**	0.67**	0.49*	<b>0.95**</b>	<b>0.96**</b>	<b>0.82**</b>	0.31	0.57**	<b>1</b>			
	Fe	<b>0.74**</b>	<b>0.71**</b>	0.47*	0.49*	<b>0.71**</b>	0.66**	<b>0.7**</b>	0.66**	0.54**	<b>0.9**</b>	<b>0.998**</b>	<b>0.84**</b>	-0.36	0.59**	<b>0.97**</b>	<b>1</b>		
	Cu	0.67**	<b>0.73**</b>	0.25	<b>0.79**</b>	0.65**	0.56**	<b>0.92**</b>	<b>0.73**</b>	0.59**	<b>0.79**</b>	0.84**	<b>0.9996**</b>	0.44*	0.14	<b>0.82**</b>	<b>0.84**</b>	<b>1</b>	

Note: r>0.70 are bold.

\*\*p<0.01. \*p<0.05. Correlation not statistically significant is without superscript.

N=31 for correlations between OP<sup>DTT</sup>, N=29 for correlations between OP<sup>DTT</sup> and PM components.

**Table S2.** Pearson's r between OP<sup>DTT</sup> m<sup>-3</sup> and PM chemical components at GT (N=34) and RS (N=29) sites.

GT	OC	EC	WS				Total				
			K	Mn	Fe	Cu	K	Mn	Fe	Cu	
Method1	OP <sup>WS-DTT</sup>	<b>0.79**</b>	<b>0.84**</b>	0.63**	0.46*	0.49*	<b>0.77**</b>	0.53**	0.43*	0.36	<b>0.78**</b>
	OP <sup>sM-DTT</sup>	<b>0.71**</b>	0.66**	0.28*	0.44**	0.45**	0.4*	0.35*	0.38	0.2	0.37*
	OP <sup>Total-DTT-1</sup>	<b>0.76**</b>	<b>0.81**</b>	0.51**	0.46*	0.54**	<b>0.74**</b>	0.39*	0.41*	0.38*	<b>0.72**</b>
Method2	OP <sup>Total-DTT-2</sup>	0.51**	0.44*	0.27	0.40*	0.09	0.62**	0.15	0.37*	0.23	0.59**
	OP <sup>WI-DTT-2</sup>	0.44*	0.25	-0.31	0.46*	-0.39	0.53**	-0.28	0.32	0.13	0.53**
Method3	OP <sup>Total-DTT-3</sup>	0.66**	<b>0.78**</b>	<b>0.82**</b>	0.69**	0.48*	<b>0.76**</b>	0.69**	<b>0.73**</b>	<b>0.71**</b>	<b>0.78**</b>
	OP <sup>WI-DTT-3</sup>	0.44*	0.48**	0.55**	0.57**	0.26	0.38	0.50*	0.66**	0.63**	0.56**
RS	OP <sup>WS-DTT</sup>	<b>0.83**</b>	<b>0.79**</b>	0.67**	0.43*	<b>0.88**</b>	0.54**	0.69**	0.48*	0.57**	0.40
Method1	OP <sup>sM-DTT</sup>	<b>0.72**</b>	<b>0.72**</b>	0.48**	0.13	<b>0.73**</b>	0.65**	0.59**	0.18	0.53**	0.38
	OP <sup>Total-DTT-1</sup>	<b>0.77**</b>	<b>0.76**</b>	0.67**	0.28	<b>0.80**</b>	0.63**	0.67**	0.39*	0.61**	0.42*
	OP <sup>Total-DTT-2</sup>	0.68**	0.52**	0.53**	0.45*	0.09	0.44*	0.48*	0.59**	0.57**	0.65**
Method2	OP <sup>WI-DTT-2</sup>	0.68**	0.51**	0.50*	0.48*	0.07	0.42*	0.42*	0.61**	0.66**	0.66**
	OP <sup>Total-DTT-3</sup>	<b>0.71**</b>	0.68**	0.6**	0.56**	0.49*	0.55**	0.67**	0.66**	0.66**	<b>0.72**</b>
	OP <sup>WI-DTT-3</sup>	-0.34	-0.37	-0.47*	-0.37	-0.40*	-0.40*	-0.43*	0.31	-0.39*	0.43*

Note: Water-insoluble OP<sup>WI-DTT</sup> obtained by method 2 and 3 is calculated by OP<sup>WI-DTT</sup> = OP<sup>Total-DTT</sup> - OP<sup>WS-DTT</sup>.  
 $r > 0.70$  are bold.  
\*\*p-value<0.01. \*p-value<0.05. The correlation not statistically significant is without superscript and greyed out.

**Table S3.** OP<sup>WS-DTT</sup>/m<sup>3</sup> and OP<sup>Total-DTT</sup>/m<sup>3</sup> (nmol/min/m<sup>3</sup>)

Filter type	GT			RS		
	OP <sup>WS-DTT</sup>	OP <sup>Total-DTT</sup>	$\frac{OP^{WS-DTT}}{OP^{Total-DTT}}$	OP <sup>WS-DTT</sup>	OP <sup>Total-DTT</sup>	$\frac{OP^{WS-DTT}}{OP^{Total-DTT}}$
Quartz	0.20 ± 0.04 N=35	0.32 ± 0.06 N=35	65 ± 10% N=35	0.21 ± 0.03 N=32	0.34 ± 0.05 N=33	62 ± 12% N=32
	0.13 ± 0.03 N=23	0.21 ± 0.04 N=23	65 ± 14% N=23	0.18 ± 0.02 N=24	0.31 ± 0.04 N=24	58 ± 10% N=24

**Table S4.** The OP variance on Teflon versus quartz filters assessed by the F-test in ANOVA.

	F	F <sub>critical</sub> for $\alpha = 0.05$
GT-OP <sup>WS-DTT</sup>	2.082	4.013
RS-OP <sup>WS-DTT</sup>	0.499	4.020
GT-OP <sup>Total-DTT</sup>	2.084	4.013
RS-OP <sup>Total-DTT</sup>	0.159	4.016

\*Null hypothesis assumes that there is no significant difference between Teflon and quartz filters.

\*F < F<sub>critical</sub> when the null hypothesis is true with significance level of 0.05.

**Table S5.** Summary of concentrations of measured PM components.

	Water-soluble		Total	
	GT	RS	GT	RS
K, ng/m <sup>3</sup>	57.49±28.08 N=28	69.79±26.56 N=29	92.54±56.05 N=28	95.97±31.63 N=28
Mn, ng/m <sup>3</sup>	1.40±0.85 N=29	3.32±1.20 N=29	2.73±1.64 N=29	7.02±2.21 N=29
Fe, ng/m <sup>3</sup>	13.94±5.04 N=29	33.25±11.36 N=29	136.69±70.72 N=29	414.41±116.54 N=29
Cu, ng/m <sup>3</sup>	18.17±7.27 N=28	22.03±8.29 N=28	35.23±18.40 N=29	37.20±15.94 N=29
OC, µg/m <sup>3</sup>	-	-	2.19±0.90 N=33	2.92±0.82 N=31
EC, µg/m <sup>3</sup>	-	-	0.54±0.22 N=32	1.68±0.41 N=31

**Table S6.** Coefficients of divergence (CODs) for the paired GT-RS site.

	Quartz filters			Teflon filters		
	EC	OC	OP <sup>WS-DTT</sup>	OP <sup>Total-DTT</sup>	OP <sup>WS-DTT</sup>	OP <sup>Total-DTT</sup>
Coefficients of divergence (CODs)	0.52	0.18	0.06	0.08	0.19	0.23

**Program code for modified automated OP<sup>Total-DTT</sup> system** (Address 1: pump A; Address 2: pump B).

Line	Line Label	Address	Command	Command Data
1		2	CONSTANT <varName> = <float>	dILarge,12
2		2	CONSTANT <varName> = <float>	AirLarge,5
3		2	CONSTANT <varName> = <float>	WasteLarge,6
4		2	CONSTANT <varName> = <float>	Tris,11
5		2	CONSTANT <varName> = <float>	TCA,10
6		2	CONSTANT <varName> = <float>	LWCC,9
7		2	CONSTANT <varName> = <float>	DTNB,1
8		2	CONSTANT <varName> = <float>	IVLarge,4
9		1	CONSTANT <varName> = <float>	dISmall,6
10		1	CONSTANT <varName> = <float>	AirSmall,4
11		1	CONSTANT <varName> = <float>	WasteSmall,5
12		1	CONSTANT <varName> = <float>	DTT,3
13		1	CONSTANT <varName> = <float>	IVSmall,2
14		1	CONSTANT <varName> = <float>	RVSmall,1
15				

16					
17	PreloadTCA	2	VALVE_PORT = <int> [CCW]	TCA	
18		2	POSITION <float> [IMM or SYNC]	1000	
19		2	VALVE_PORT = <int> [CCW]	WasteLarge	
20		2	POSITION <float> [IMM or SYNC]	0	
21	PreloadTris	2	VALVE_PORT = <int> [CCW]	Tris	
22		2	POSITION <float> [IMM or SYNC]	1000	
23		2	VALVE_PORT = <int> [CCW]	WasteLarge	
24		2	POSITION <float> [IMM or SYNC]	0	
25					
26	PreloadDTT	1	VALVE_PORT = <int> [CCW]	DTT	
27		1	POSITION <float> [IMM or SYNC]	250	
28		1	VALVE_PORT = <int> [CCW]	WasteSmall	
29		1	POSITION <float> [IMM or SYNC]	0	
30	PreloadDTNB	2	VALVE_PORT = <int> [CCW]	DTNB	
31		2	POSITION <float> [IMM or SYNC]	500	
32		2	VALVE_PORT = <int> [CCW]	WasteLarge	
33		2	POSITION <float> [IMM or SYNC]	0	
34					
35	SetHomePosition	1	SET out2 = <bit>	1	
36		1	SET out2 = <bit>	0	
37		1	SET out2 = <bit>	1	
38		1	SET out1 = <bit>	1	
39		1	DELAY <float>	1	
40					
41			DO		
42	CleanLarge+Small1		DO		
43		2	VALVE_PORT = <int> [CCW]	dILarge	
44		2	SET speed = <float>	400	
45		2	POSITION <float> [IMM or SYNC]	5000	
46		2	VALVE_PORT = <int> [CCW]	WasteLarge	
47		2	POSITION <float> [IMM or SYNC]	0	
48		1	VALVE_PORT = <int> [CCW]	dISmall	
49		1	POSITION <float> [IMM or SYNC]	250	
50		1	VALVE_PORT = <int> [CCW]	WasteSmall	
51		1	POSITION <float> [IMM or SYNC]	0	
52			LOOP <int>	1	
53					
54	LoadReactionVial1	1	VALVE_PORT = <int> [CCW]	DTT	

55		1	POSITION <float> [IMM or SYNC]	250
56		1	VALVE_PORT = <int> [CCW]	RVSmall
57		1	POSITION <float> [IMM or SYNC]	0
58		1	VALVE_PORT = <int> [CCW]	DTT
59		1	POSITION <float> [IMM or SYNC]	100
60		1	VALVE_PORT = <int> [CCW]	dISmall
61		1	POSITION <float> [IMM or SYNC]	250
62		1	VALVE_PORT = <int> [CCW]	RVSmall
63		1	POSITION <float> [IMM or SYNC]	0
64		1	VALVE_PORT = <int> [CCW]	dISmall
65		1	POSITION <float> [IMM or SYNC]	200
66		1	VALVE_PORT = <int> [CCW]	RVSmall
67		1	POSITION <float> [IMM or SYNC]	0
68		1	SET speed = <float>	100
69			DO	
70		1	VALVE_PORT = <int> [CCW]	AirSmall
71		1	POSITION <float> [IMM or SYNC]	250
72		1	VALVE_PORT = <int> [CCW]	RVSmall
73		1	POSITION <float> [IMM or SYNC]	0
74		1	VALVE_PORT = <int> [CCW]	AirSmall
75		1	POSITION <float> [IMM or SYNC]	250
76		1	VALVE_PORT = <int> [CCW]	RVSmall
77		1	POSITION <float> [IMM or SYNC]	0
78			LOOP <int>	10
79		1	SET speed = <float>	30
80		1	VALVE_PORT = <int> [CCW]	dISmall
81		1	POSITION <float> [IMM or SYNC]	250
82		1	VALVE_PORT = <int> [CCW]	WasteSmall
83		1	POSITION <float> [IMM or SYNC]	0
84		1	VALVE_PORT = <int> [CCW]	dISmall
85		1	POSITION <float> [IMM or SYNC]	250
86		1	VALVE_PORT = <int> [CCW]	WasteSmall
87		1	POSITION <float> [IMM or SYNC]	0
88		2	DELAY <float>	40
89				
90	ChangePort	1	SET out1 = <bit>	0
91		1	SET out1 = <bit>	1
92		2	DELAY <float>	1
93				

94	LoadTCA1		DO	
95		2	VALVE_PORT = <int> [CCW]	TCA//X10 diluted
96		2	SET speed = <float>	400
97		2	POSITION <float> [IMM or SYNC]	1000
98		2	VALVE_PORT = <int> [CCW]	IVLarge
99		2	POSITION <float> [IMM or SYNC]	0
100		2	VALVE_PORT = <int> [CCW]	AirLarge
101		2	POSITION <float> [IMM or SYNC]	1000
102		2	VALVE_PORT = <int> [CCW]	IVLarge
103		2	POSITION <float> [IMM or SYNC]	0
104		2	VALVE_PORT = <int> [CCW]	dILarge
105		2	POSITION <float> [IMM or SYNC]	1500
106		2	VALVE_PORT = <int> [CCW]	WasteLarge
107		2	POSITION <float> [IMM or SYNC]	0
108				
109	CleanLWCC1	2	VALVE_PORT = <int> [CCW]	dILarge
110		2	POSITION <float> [IMM or SYNC]	5000
111		2	VALVE_PORT = <int> [CCW]	LWCC
112		2	POSITION <float> [IMM or SYNC]	0
113				
114				
115	Draw	1	VALVE_PORT = <int> [CCW]	RVSmall
116		1	SET speed = <float>	30
117		1	POSITION <float> [IMM or SYNC]	250
118		1	VALVE_PORT = <int> [CCW]	WasteSmall
119		1	POSITION <float> [IMM or SYNC]	0
120		1	VALVE_PORT = <int> [CCW]	RVSmall
121		1	POSITION <float> [IMM or SYNC]	250
122		1	VALVE_PORT = <int> [CCW]	WasteSmall
123		1	POSITION <float> [IMM or SYNC]	0
124		1	VALVE_PORT = <int> [CCW]	RVSmall
125		1	SET speed = <float>	5
126		1	POSITION <float> [IMM or SYNC]	250
127		1	DELAY <float>	5
128		1	VALVE_PORT = <int> [CCW]	WasteSmall
129		1	SET speed = <float>	40
130		1	POSITION <float> [IMM or SYNC]	0
131			DO	

132		1	VALVE_PORT = <int> [CCW]	RVSmall
133		1	SET speed = <float>	5
134		1	POSITION <float> [IMM or SYNC]	250
135		1	DELAY <float>	15
136		1	VALVE_PORT = <int> [CCW]	WasteSmall
137		1	SET speed = <float>	40
138		1	POSITION <float> [IMM or SYNC]	0
139			LOOP <int>	3
140		1	VALVE_PORT = <int> [CCW]	RVSmall
141		1	SET speed = <float>	5
142		1	POSITION <float> [IMM or SYNC]	250
143		1	VALVE_PORT = <int> [CCW]	WasteSmall
144		1	POSITION <float> [IMM or SYNC]	180
145		1	VALVE_PORT = <int> [CCW]	IVSmall
146		1	POSITION <float> [IMM or SYNC]	80
147		1	VALVE_PORT = <int> [CCW]	RVSmall
148		1	POSITION <float> [IMM or SYNC]	0
149		1	SET speed = <float>	40
150			DO	
151		1	VALVE_PORT = <int> [CCW]	AirSmall
152		1	POSITION <float> [IMM or SYNC]	250
153		1	VALVE_PORT = <int> [CCW]	RVSmall
154		1	POSITION <float> [IMM or SYNC]	0
155		1	VALVE_PORT = <int> [CCW]	AirSmall
156		1	POSITION <float> [IMM or SYNC]	250
157		1	VALVE_PORT = <int> [CCW]	RVSmall
158		1	POSITION <float> [IMM or SYNC]	0
159		1	VALVE_PORT = <int> [CCW]	AirSmall
160		1	POSITION <float> [IMM or SYNC]	250
161		1	VALVE_PORT = <int> [CCW]	IVSmall
162		1	POSITION <float> [IMM or SYNC]	0
163			LOOP <int>	3
164				
165	LoadTris1	2	VALVE_PORT = <int> [CCW]	Tris//X5 diluted
166		2	POSITION <float> [IMM or SYNC]	2000
167		2	VALVE_PORT = <int> [CCW]	IVLarge
168		2	POSITION <float> [IMM or SYNC]	0
169		2	VALVE_PORT = <int> [CCW]	AirLarge
170		2	POSITION <float> [IMM or SYNC]	1000

171		2	VALVE_PORT = <int> [CCW]	IVLarge
172		2	POSITION <float> [IMM or SYNC]	0
173		2	VALVE_PORT = <int> [CCW]	dILarge
174		2	POSITION <float> [IMM or SYNC]	5000
175		2	VALVE_PORT = <int> [CCW]	WasteLarge
176		2	POSITION <float> [IMM or SYNC]	0
177				
178	LoadDTNB1	2	VALVE_PORT = <int> [CCW]	DTNB//X50 diluted
179		2	POSITION <float> [IMM or SYNC]	500
180		2	VALVE_PORT = <int> [CCW]	IVLarge
181		2	POSITION <float> [IMM or SYNC]	0
182		2	VALVE_PORT = <int> [CCW]	IVLarge
183		2	POSITION <float> [IMM or SYNC]	5000
184		2	VALVE_PORT = <int> [CCW]	IVLarge
185		2	POSITION <float> [IMM or SYNC]	0
186		2	VALVE_PORT = <int> [CCW]	AirLarge
187		2	POSITION <float> [IMM or SYNC]	5000
188		2	VALVE_PORT = <int> [CCW]	IVLarge
189		2	POSITION <float> [IMM or SYNC]	0
190				
191	IVtoLWCC1	2	VALVE_PORT = <int> [CCW]	IVLarge
192		2	POSITION <float> [IMM or SYNC]	4700
193		2	VALVE_PORT = <int> [CCW]	WasteLarge
194		2	POSITION <float> [IMM or SYNC]	4000
195		2	VALVE_PORT = <int> [CCW]	LWCC
196		2	SET speed = <float>	400
197		2	POSITION <float> [IMM or SYNC]	0
198				
199	RinselV1	2	VALVE_PORT = <int> [CCW]	IVLarge
200		2	SET speed = <float>	400
201		2	POSITION <float> [IMM or SYNC]	5000
202		2	VALVE_PORT = <int> [CCW]	WasteLarge
203		2	POSITION <float> [IMM or SYNC]	0
204			DO	
205		2	VALVE_PORT = <int> [CCW]	dILarge
206		2	POSITION <float> [IMM or SYNC]	5000
207		2	VALVE_PORT = <int> [CCW]	IVLarge
208		2	POSITION <float> [IMM or SYNC]	0

209		2	VALVE_PORT = <int> [CCW]	dILarge
210		2	POSITION <float> [IMM or SYNC]	2000
211		2	VALVE_PORT = <int> [CCW]	IVLarge
212		2	POSITION <float> [IMM or SYNC]	0
213		2	VALVE_PORT = <int> [CCW]	IVLarge
214		2	POSITION <float> [IMM or SYNC]	5000
215		2	VALVE_PORT = <int> [CCW]	WasteLarge
216		2	POSITION <float> [IMM or SYNC]	0
217		2	VALVE_PORT = <int> [CCW]	IVLarge
218		2	POSITION <float> [IMM or SYNC]	5000
219		2	VALVE_PORT = <int> [CCW]	WasteLarge
220		2	POSITION <float> [IMM or SYNC]	0
221			LOOP <int>	2
222			LOOP <int>	5
223				
224	RinseRV1		DO	
225			DO	
226		1	VALVE_PORT = <int> [CCW]	dISmall
227		1	POSITION <float> [IMM or SYNC]	250
228		1	VALVE_PORT = <int> [CCW]	RVSmall
229		1	POSITION <float> [IMM or SYNC]	0
230			LOOP <int>	4
231			DO	
232		1	VALVE_PORT = <int> [CCW]	AirSmall
233		1	POSITION <float> [IMM or SYNC]	250
234		1	VALVE_PORT = <int> [CCW]	RVSmall
235		1	POSITION <float> [IMM or SYNC]	0
236			LOOP <int>	4
237			LOOP <int>	2
238				
239	RecleanLWCC1	2	VALVE_PORT = <int> [CCW]	dILarge
240		2	POSITION <float> [IMM or SYNC]	5000
241		2	VALVE_PORT = <int> [CCW]	LWCC
242		2	POSITION <float> [IMM or SYNC]	0
243				
244				
245	ChangeSample	1	SET out1 = <bit>	0
246		1	SET out1 = <bit>	1
247			LOOP <int>	8