

Supplement of Atmos. Meas. Tech., 11, 369–383, 2018
<https://doi.org/10.5194/amt-11-369-2018-supplement>
© Author(s) 2018. This work is distributed under
the Creative Commons Attribution 4.0 License.



Supplement of

**Modification, calibration, and performance of the Ultra-High Sensitivity
Aerosol Spectrometer for particle size distribution and volatility
measurements during the Atmospheric Tomography Mission (ATom)
airborne campaign**

Agnieszka Kupc et al.

Correspondence to: Agnieszka Kupc (agnieszka.kupc@noaa.gov)

The copyright of individual parts of the supplement might differ from the CC BY 4.0 License.

Supplementary Material

Table S1. List of items added to the UHSAS flow system

Part of the flow system	Item added	Specifications
Sample flow	Laminar flow element (LFE)	ID=0.069 cm Length=17.5 cm Laminar flow range: 0-0.1 L min ⁻¹
	Differential pressure transducer	Alicat, P-5in-dp, range: 0-2" H ₂ O
Sheath flow	Volumetric flow controller (VFC) replaces needle valve	Alicat, MC-15LPM, operated in volume flow control mode

Table S2. Thermodenuder components and dimensions

Part	Model	Manufacturer
Temperature controller	CN32PT-224-C24	Omega Engineering Inc., Stamford, CT, USA
Solid state relay	120D25	OPTO 22, Temecula, CA, USA
Platinum resistance temperature detector (RTD)	HEL-707-U-1-12-00	Honeywell Sensing and Control, Golden Valley, MN, USA
Cylindrical cartridge heater	HDC00066	Honeywell Sensing and Control, Golden Valley, MN, USA
Housing tube	stainless steel, ID=1.12 cm	
Perforated tube insert	PS4542A: Stainless Steel 17-4 PH	Xometry, Inc., Gaithersburg, MD, USA
Activated carbon fiber cloth	FlexZorb Thickness 0.3 mm	Calgon Carbon Corporation, Moon Township, Pennsylvania, USA

Table S3. Estimated relative uncertainties in aerosol number (σ_N), surface (σ_S) and volume (σ_V) at STP conditions. Uncertainties are calculated for representative size distributions in the marine boundary layer (MBL) and free troposphere (FT) using different averaging times.

Date and location	Integration time (s)	Counts	N	S	V	P	σ_N (%)	σ_S (%)	σ_V (%)
			(cm ⁻³)	($\mu\text{m}^2\text{cm}^{-3}$)	($\mu\text{m}^3\text{cm}^{-3}$)	(hPa)			
2017/02/05	1	31	34.1	2.376	0.074	1101	±18	+29.5/-43.0	+35.0/-55.8
MBL	10	297	27.4	2.888	0.177	1101	±5.9	+17.4/-29.7	+22.9/-40.5
32 °S	60	1654	27.4	2.81	0.14	1104	±2.6	+14.1/-26.6	+19.7/-38.0
2017/02/10	1	134	138.2	19.614	1.636	1061	±8.7	+20.2/-31.6	+25.7/-42.2
MBL	10	1582	150.3	26.065	2.779	1058	±2.7	+14.2/-25.2	+19.7/-36.0
59.77 °S	60	8705	145.9	25.585	2.628	1061	±1.4	+12.9/-23.9	+18.5/-34.7
2017/01/26	1	6	35.5	0.938	0.015	294	±40.8	+52.4/-70.8	+57.9/-86.3
FT	10	40	21.7	0.458	0.007	293	±15.8	+27.4/-47.1	+32.9/-62.9
4 °N	60	255	24.0	0.597	0.01	294	±6.3	+17.9/-36.4	+23.4/-50.9
2017/01/26	1	53	442.4	10.119	0.156	256	±13.8	+25.3/-44.4	+30.8/-59.5
FT	10	541	411.9	12.775	0.262	256	±4.4	+15.9/-33.1	+21.4/-46.3
18.7 °N	60	3208	438.9	13.994	0.361	256	±2.0	+13.5/-30.5	+19.0/-41.7




Fig.S1. UHSAS-2 sizing response to pressure change as a function of bin number for a mixture of four PSL particle sizes. Bin uncertainty, obscured by the symbols, is based on the uncertainty in a Gaussian fit to the size distribution histogram.