

Data inversion methods to determine sub-3 nm aerosol size distributions using the Particle Size Magnifier

Runlong Cai^{1,2,#}, Dongsen Yang^{3,#}, Lauri R. Ahonen², Linlin Shi³, Frans Korhonen², Yan Ma³, Jiming Hao¹, Tuukka Petäjä², Jun Zheng^{3,*}, Juha Kangasluoma^{2,4}, and Jingkun Jiang^{1,*}

¹ State Key Joint Laboratory of Environment Simulation and Pollution Control, School of Environment, Tsinghua University, 100084 Beijing, China

² Institute for Atmospheric and Earth System Research / Physics Faculty of Science, University of Helsinki, P.O. Box 64, 00014 Helsinki, Finland

³ Collaborative Innovation Center of Atmospheric Environment and Equipment Technology, Nanjing University of Information Science & Technology, 210044 Nanjing, China

⁴ Aerosol and Haze Laboratory, Beijing Advanced Innovation Center for Soft Matter Science and Engineering, Beijing University of Chemical Technology, 100029 Beijing, China

#: Runlong Cai and Dongsen Yang contribute equally to this work

*: Correspondence to: J. Jiang (jiangjk@tsinghua.edu.cn) and J. Zheng (zheng.jun@nuist.edu.cn)

Abstract. Measuring particle size distribution accurately down to approximately 1 nm is needed for studying atmospheric new particle formation. The scanning particle size magnifier (PSM) using diethylene glycol as working fluid has been used for measuring sub-3 nm atmospheric aerosol. A proper inversion method is required to recover the particle size distribution from PSM raw data. Similar to other aerosol spectrometers and classifiers, PSM inversion can be deduced to a problem described by the Fredholm integral equation of the first kind. We tested the performance of the stepwise method, the kernel function method (Lehtipalo et al., 2014), the H&A linear inversion method (Hagen and Alofs, 1983), and the expectation-maximization (EM) algorithm. The stepwise method and the kernel function method were used in previous studies on PSM. The H&A method and the expectation-maximization algorithm were used in data inversion for the electrical mobility spectrometers and the diffusion batteries (Maher and Laird., 1985), respectively. In addition, Monte Carlo simulation and laboratory experiments were used to test the accuracy and precision of the particle size distributions recovered using four inversion methods. When all of the detected particles are larger than 3 nm, the stepwise method may report false sub-3 nm particle concentrations because of assuming an infinite resolution, while the kernel function method and the H&A method occasionally reports false sub-3 nm particles because of using the unstable least square method. The accuracy and precision of the recovered particle size distribution using the EM algorithm are the best among the tested four inversion methods. Compared to the kernel function method, the H&A method reduces the uncertainty while keeping a similar computational expense. The measuring uncertainties in the present scanning mode may contribute to the uncertainties of the recovered particle size distributions. We suggest using the EM algorithm to retrieve the particle size distributions using the particle number concentrations recorded by the PSM. Considering the relatively high computation expenses of the EM algorithm, the H&A method is recommended to be used for preliminary data analysis. We also gave practical suggestions on PSM operation based on the inversion analysis.

1 Introduction

The particle size magnifier (PSM) using diethylene glycol as working fluid (Vanhanen et al., 2011) is widely used in new particle formation studies (Kulmala et al., 2012; Kulmala et al., 2013; Kontkanen et al., 2017) and other industrial applications (Nosko et al., 2016; Ahonen et al., 2017). A PSM can report particle size distributions in the 1-3 nm size range, which is a key size region in the nucleation study. Particles in the PSM grow into larger sizes due to the condensation of super saturated diethylene glycol, and these particles after the initial growth are detected using a downstream condensation particle counter (CPC). The PSM detection efficiency (the CPC is included if not specially mentioned) of particles with a certain diameter is a function of the super saturation ratio of diethylene glycol. Increasing the flow rate passing through the chamber containing saturated diethylene glycol vapour, i.e., the saturator flow rate, can enhance the super saturation ratio thus the particle detection efficiencies. The total particle number concentration detected by the PSM varies with the varying saturator flow rate, and one can determine the particle size distribution according to the observed relationship between the particle number concentration and the saturator flow rate.

A proper inversion method is required to recover the particle size distribution using the recorded relationship between the particle number concentration and the saturator flow rate. The stepwise method and the kernel function method were used in previous studies for PSM inversion (Lehtipalo et al., 2014). The stepwise method is a one-to-one linear inversion method using the relationship between the 50% cut-off size and the saturator flow rate, which essentially assumes infinite sizing resolutions, i.e., the particles of a specific size are activated at a certain saturator flow rate. However, such an approximation may lead to non-negligible errors due to the relatively low resolution of the PSM. The kernel function method accounts for the detection efficiency curves, and the particle size distribution is recovered using the non-negative least square method.

Although the uncertainties of the particle size distribution determined using the PSM was discussed recently (Kangasluoma and Kontkanen, 2017), the uncertainties introduced during the data inversion have not been systematically addressed. There are always measuring uncertainties in practical conditions, thus one should account for the measuring errors when evaluating the performance of a data inversion method. Because of the relatively low resolution of the PSM, the matrix connecting the particle size distribution and the observed total number concentration is usually ill-conditioned. The kernel function method may theoretically recover the observed particle size distribution when there are no random errors. However, it sometimes leads to large uncertainties when there are small random errors because of the instability of the least square method at a near collinear data set (Ellis, 1998).

The equation mapping the particle size distribution to the particle number concentration detected by the PSM is the Fredholm integral equation of the first kind, which arises in many fields, e.g., when studying the molecular dynamics in

1 complex systems (Schäfer et al., 1996) and characterizing the transfer function of an ion drift tube (Buckley and Hogan,
 2 2017). Various types of aerosol spectrometers or classifiers, e.g., cascade impactors, optical particle spectrometers,
 3 electrical mobility spectrometers, and diffusional barriers, classify particles according to the signals recorded by a number
 4 of channels. There is no strict one-to-one relationship between the particle number concentration in a certain size range
 5 and the detected signal in a certain channel because of the finite sizing resolutions. The inversion methods used in the
 6 previous aerosol spectrometers can possibly be applied to address the PSM inversion problem. The review of the inversion
 7 methods for aerosol spectrometers can be found in Kandlikar and Ramachandran (1999), Knutson (1999), and
 8 Ramachandran and Cooper (2011).

9 An inversion method with less prior information on the particle size distribution is preferable for the PSM inversion
 10 problem. It is impossible to obtain a continuous particle size distribution using a finite number of the detected signals
 11 without any constraints, e.g., a known analytical expression to describe the size distribution. Some inversion methods rely
 12 on a presumed particle size distribution formula (Fuchs et al., 1962; Raabe, 1978; Ramachandran and Kandlikar, 1996)
 13 or prior information on the detection efficiencies (e.g., Onischuk et al., 2017). However, approximating various shapes
 14 of the observed sub-3 nm particle size distributions or the PSM detection efficiency curves using a specific formula may
 15 lead to relatively large uncertainties. Some methods are feasible in certain conditions, however, sometimes they are not
 16 convergent or may lead to high-frequency oscillations (Twomey, 1975; Ferri et al., 1989) due to practical random errors.
 17 Some methods use smoothing criterions to deal with the oscillations (Markowski, 1987; Winklmayr et al., 1990), however,
 18 they occasionally report an over-smoothed size distribution because of the relatively low resolution and limited size bins
 19 of the PSM. The Tikhonov regularisation (Tikhonov, 1963) uses a regularisation parameter to determine the balance of
 20 smoothing and the agreement with the recorded signals, thus the inverted result may be affected by the method to
 21 determine the regularisation parameter (e.g., Wahba, 1977; Hansen, 1992).

22 Based on the reasons mentioned above, we chose the H&A linear inversion method (Hagen and Alofs, 1983) and the
 23 expectation-maximization algorithm, and tested the feasibility to apply these methods in the PSM inversion problem. The
 24 H&A method is a linear inversion method used in size distribution multi-charge correction, which has the relatively low
 25 computational expense. The expectation-maximization algorithm is an iterative method based on probability theory
 26 (Dempster et al., 1977), and it was used to reconstruct particle size distributions from diffusion battery data (Maher and
 27 Laird, 1985; Wu et al., 1989).

28 In this study, we tested the performance of the stepwise method, the kernel function method, the H&A method, and the
 29 expectation-maximization algorithm in PSM inversion. Experiments and Monte Carlo simulations accounting for random
 30 errors were used to evaluate the sizing accuracies and the uncertainties of the particle size distributions recovered using

four inversion methods. The influence of particles larger than 3 nm on the reported sub-3 nm particle size distributions was discussed. Based on the comparison, the methods with comparatively low uncertainties and high stabilities were recommended to address the PSM inversion problem.

2 Theory

2.1 PSM measuring theory

A PSM measures the total particle number concentration of the activated particles. The sampled aerosol flow is mixed with a high-temperature flow containing saturated diethylene glycol coming from the saturator, and then the mixed flow passes through a low-temperature growth tube. The particles large than a specific diameter can overcome the Kelvin effect and grow into larger sizes due to the condensation of super saturated diethylene glycol. The detection efficiency is mainly determined by the particle diameter and the saturator flow rate. The chemical compositions and charging state may affect the detection efficiencies (Kangasluoma et al., 2013; Kangasluoma et al., 2016a) and lead to errors in the reported particle size distributions (Kangasluoma and Kontkanen, 2017), however, we mainly focus on the inversion method in this study and assume the detection efficiency is only size dependent at a certain saturator flow rate. Since the temperatures in the saturator and the growth tube are fixed, a higher saturator flow rate leads to a higher super saturation ratio of diethylene glycol in the growth tube hence higher detection efficiencies (Fig. 1a). See Section 3.1 for the details on how to obtain the detection efficiency curves. The detected total particle number concentration varies with the varying saturator flow rate when the particle size distribution keeps unchanged. The relationship between the detected total particle concentration, R , the saturator flow rate, s , and the particle size distribution function, n , can be expressed in the Fredholm integral equation of the first kind:

$$R_i = \int_0^{+\infty} \eta(s_i, d_p) \times n \times dd_p + \varepsilon_i, \quad (1)$$

where R_i is the number concentration recorded at the i^{th} saturator flow rate, s_i ; d_p is the electrical mobility diameter since the calibrating particles are classified according to their electrical mobility; η is the overall detection efficiency determined by s and d_p , including the detection efficiency and the sampling efficiency; n is the probability density of particle number concentration (particle size distribution function), dN/dd_p and N is the accumulated number concentration of particles smaller than d_p ; and ε_i is the error in the recorded particle concentration at s_i .

There are many potential sources of the error, ε . For instance, the uncertainties in the calibrated detection efficiencies, the systematic errors caused by the non-ideal fitting formula of the detection efficiency curves, the CPC counting uncertainties, the uncertainties in the super saturation ratio due to fluctuations in the flow rate and temperature, and the

unstable aerosol source will all contribute to the difference between the detected number concentration and the expected particle concentration assuming there is no error.

As shown in Fig. 1b, the kernel function of the PSM, K , is defined as the derivative of the detection efficiency, η , with respect to the saturator flow rate, s . The area of the kernel function is equal to the difference between the detection efficiencies at the maximum and minimum saturator flow rates. Here we define r as the derivative of the detected number concentration, R , with respect to s . According to Eq. 1, the relationship between r and s is also a Fredholm integral equation of the first kind:

$$r_m = \int_0^{+\infty} K(s_m, d_p) \times n \times dd_p + \varepsilon'_m, \quad (2)$$

where r_m is the r at the m^{th} saturator flow rate, s_m ; and ε'_m is the error in r_m . Although r is theoretically defined as the derivative of R , practically one can only approximate r using the difference between two adjacent R_i over the increment in s_i and approximate s_m with the mean value of the two corresponding s_i . These approximations also contribute to the uncertainties, ε'_m in addition to the aforementioned sources for ε_i .

When using a PSM to determine particle size distributions, the PSM records the varying total particle concentration, R_i , and the corresponding saturator flow rate, s_i . The saturator flow rate may vary continuously in the scanning mode or fixed at different flow rates in the stepping mode. The particle size distributions are recovered using the recorded relationship between R_i and s_i or the relationship between the approximated r_m and s_m .

The sizing ability of the PSM can be described using the size resolution. Similar to the definition of the sizing resolution of a differential mobility analyser (DMA, Flagan, 1999) to classify particles according to their electrical mobility, we define the resolution of a PSM as:

$$\text{Res} = \frac{s^*}{\Delta s} \quad (3)$$

where Res is the resolution at s^* ; s^* is the peak saturator flow rate of a kernel function; and Δs is the full width at half maximum of the kernel function peak. A relationship between the saturator flow rate and the electrical mobility diameter is defined to straightforwardly relate the resolution and the particle diameter. The peak saturator flow rate, s^* is defined as the corresponding saturator flow rate of the particle diameter. This definition is similar to but different from the definition using the saturator flow rate at the half maximum detection efficiency in Lehtipalo et al. (2014) and in the commercialized PSM. The sizing resolution of a PSM can be estimated according to the relationship between s and d_p , as shown in Fig. 2. However, the resolution alone is not sufficient to indicate the possible reported size range when the PSM is measuring monodisperse particles because the kernel functions are asymmetric and the inversion method also affect

the reconstructed peaks. One should especially keep in mind that the PSM does not measure particle diameter because the relationship between s and d_p is only a definition rather than an intrinsic correlation. A PSM only record the varying particle concentration against the varying saturator flow rate (as indicated in Eqs. 1 and 2). One can only obtain the particle diameters via proper data inversion.

2.2 The stepwise method

The resolution of the PSM is assumed infinite in the stepwise method. Thus, the integral equation relating n and r collapses into a one-to-one corresponding relationship (Lehtipalo et al., 2014),

$$n_m = \frac{2(R_{i+1} - R_i)}{\eta(s_{\max}, d_i) + \eta(s_{\max}, d_{i+1})} \times \frac{1}{d_i - d_{i+1}} \quad (4)$$

where n_m is the particle size distribution function (dN/dd_p) at d_m ; d_m , d_i , and d_{i+1} are the corresponding half-maximum cut-off diameters of s_m , s_i , and s_{i+1} , respectively; and s_m is the mean value of s_i and s_{i+1} . The relationship between particle diameter and the saturator flow rate is determined using the saturator flow rate at the half maximum detection efficiency (Lehtipalo et al., 2014). The stepwise method does not magnify the relative error in measurement since it is a one-to-one inversion method. However, the inverted results using the stepwise method are perhaps non-negligibly affected by the relatively low resolutions of the PSM.

2.3 The kernel function method

The kernel function method assumes that the particle size distribution can be approximated using several particle size bins and the detection efficiencies of particles in each size bin are the same. The mathematical description of this approximation is:

$$r_m \approx \sum_{j=1}^J K(s_m, d_j) \times n_j \times \Delta d_j, \quad J \leq I - 1, \quad (5)$$

where d_j is the representing particle diameter of each size bin; J is the number of d_j ; n_j is the particle size distribution function (dN/dd_p) at d_j ; Δd_j is the length of each size bin; and I is the number of R_i . The symbol of \approx is to emphasize that Eq. 5 is an approximation even if there are no measuring errors because it approximates the integral with a finite discrete sum and estimates r_m using the recorded R_i . Using a matrix, Eq. 5 can be rewritten as:

$$\mathbf{r}_{(I-1) \times 1} \approx \mathbf{G}_{(I-1) \times J} \cdot \mathbf{n}_{J \times 1}, \quad J \leq I - 1 \quad (6)$$

$$\text{where } \mathbf{G}_{ij} = K(s_i, d_j) \times \Delta d_j \quad (7)$$

The subscriptions in the uppercase of Eq. 6 indicate the dimensions of the matrix and the vectors, while the subscriptions in the lowercase of Eq. 7 represent the corresponding element. The particle size distribution is obtained via solving Eq. 6 using the non-negative least square method.

2.4 The Hagen & Alofs method

The H&A method (Hagen and Alofs, 1983) was proposed to deal with the multi-charging correction problem when using a DMA. It can also be used to solve the PSM inversion problem. Similar to the kernel function method, a discrete sum is used to approximate the integral:

$$R_i = \sum_{j=1}^J \eta(s_i, d_j) \times n_j \times \Delta d_j, J \gg I \quad (8)$$

$$\mathbf{R}_{I \times 1} = \mathbf{P}_{I \times J} \cdot \mathbf{n}_{J \times 1} \quad (9)$$

Eq. 9 is the vector form for Eq. 8 and \mathbf{P} is the matrix relating n_j and \mathbf{R} . We use the symbol of $=$ in Eq. 8 and Eq. 9 rather than \approx because the H&A method requires a J much larger than I . One should increase J if the error in approximating the integral with the discrete sum is still large. Usually, J is determined as 30 times that of I considering the computational expenses. However, Eq. 8 itself is not solvable because there are more unknown variables than the equations. Thus, additional constraints are required. The H&A method assumes that any n_j can be approximated using n_i , i.e.,

$$n_j \approx f(n_i, d_j), \quad (10)$$

$$\mathbf{n}_{J \times 1} \approx \mathbf{F}_{J \times I} \cdot \mathbf{n}_{I \times 1}, \quad (11)$$

where f is the function relating n_j and \mathbf{n}_i (\mathbf{n}_i is a vector); n_i is the particle size distribution function at d_i ; n_j is estimated using more than one single n_i ; and Eq. 11 is the vector form for Eq. 10. The determination of d_i is theoretically arbitrary as long as the number of d_i is the same as the number of R_i . For the details to determine f , please refer to Hagen and Alofs (1983).

Similar to the kernel function method, the relationship between the particle size distribution and the number concentration recorded by the PSM can be described in the vector form:

$$\mathbf{R}_{I \times 1} \approx \mathbf{P}_{I \times J} \cdot \mathbf{F}_{J \times I} \cdot \mathbf{n}_{I \times 1} = \mathbf{Q}_{I \times I} \cdot \mathbf{n}_{I \times 1} \quad (12)$$

\mathbf{P} and \mathbf{F} are determined according to Eq. 8-11 and thus \mathbf{Q} is determined by η , f , and Δd_j . One can directly solve Eq. 10 (e.g., via Gaussian elimination) since \mathbf{Q} is usually non-singular. However, different from the matrix obtained from a DMA, the matrix \mathbf{Q} in PSM inversion problem is usually not a positive-definite matrix because the detected particle concentration sometimes decreases with the increasing saturator flow rate due to random errors. Simply solving Eq. 12 often obtains negative values in particle size distributions. Thus, the non-negative least square method is suggested to determine the particle size distribution in the PSM inversion problem. The H&A methods can also reconstruct the particle size distribution according to the relationship between r_m and s_m . However, using the kernel functions instead of the detection efficiencies does not necessarily improve the accuracy or precision of the results. On the contrast, we found that

using the kernel functions usually lead to larger uncertainties than using the detection efficiencies because of the errors caused by approximating r_m .

The H&A method is theoretically more stable than the kernel function method because of the more accurate assumption of the true aerosol size distribution. However, the H&A method adapted for PSM inversion may still report size distributions with large uncertainties because of using the least square method. The computational expense of the H&A method is similar to that of the kernel function method because the rate-limiting step is to solve the least square question. Their low computational expense is an advantage over other nonlinear inversion methods.

2.5 The expectation-maximization algorithm

The EM algorithm is a statistical method dealing with inversion problems with unobserved latent variables. An explanation of the EM algorithm can be found in Do and Batzoglou (2008). In the PSM inversion problem, the latent variable is R_{ij} , defined as the contribution of particles with the diameter of d_j to the detected number concentration, R_i (Maher and Laird, 1985). The algorithm obtains the recovered particle size distribution using two steps: the expectation step and the maximization step. In the expectation step, the values of R_{ij} are estimated according to Bayesian theorem:

$$R_{ij} = \frac{n_j \times \eta(s_i, d_j) \times \Delta d_j}{\sum_{j=1}^J n_j \times \eta(s_i, d_j) \times \Delta d_j} \quad (13)$$

In the maximization step, the particle size distribution function is estimated according to the maximum likelihood:

$$n_j = \frac{\sum_{i=1}^I R_{ij}}{\sum_{i=1}^I \eta(s_i, d_j) \times \Delta d_j} \quad (14)$$

The EM algorithm obtains the recovered particle size distribution by repeating the expectation step and the maximization step until convergence. The convergence can be measured by the likelihood function (Maher and Laird, 1985). The values and the number of d_j are not limited when using the EM algorithm, and a larger J can reduce the errors in approximating the integral using the discrete sum. Thus, the EM algorithm is able to report particle size distributions with more size bins compared to the stepwise method, the kernel function method, and the H&A method.

The EM algorithm is more stable compared to the algorithms based on the least square methods (Maher and Laird, 1985). The convergence of the EM algorithm has been proved (Dempster et al., 1977), however, the convergence speed is not mathematically guaranteed. Compared to the kernel function method and the H&A method, the computational expense of the EM algorithm is much higher. In addition, the EM algorithm is a greedy algorithm such that the iteration is easily trapped in a local optimum. To start the first expectation step, an initial guess of the particle size distribution is required.

We suggest the initial guess to be a vector of all ones. Note that the EM algorithm is sensitive to the initial guess and using a recovered particle size distribution obtained from another method, e.g., the stepwise method does not necessarily improve the iteration results.

3 Methods

3.1 Experiments

Laboratory experiments using particles with known peak size or size distribution were conducted to test the inversion methods (Fig. 3). Sub-10 nm tungsten oxide particles were generated using a wire generator (Peineke et al., 2006; Kangasluoma et al., 2015). In the narrow peak measurement, the negatively charged particles were classified using a high-resolution Herrmann DMA. The sizing resolutions of the Herrmann DMA in the experimental conditions were no smaller than 25 (Kangasluoma et al., 2016b). Thus, the classified aerosols out of the Herrmann DMA can be approximately regarded as monodisperse. The relationship between the Herrmann DMA voltage and the classified particle size was calibrated using standard molecular ions (Ude and de la Mora, 2005). A TSI 3068B aerosol electrometer using the same aerosol flow rate with the PSM (2.5 liters per minute, lpm) was used as the reference.

In the wide peak measurement, the particle size distributions classified using a TSI nanoDMA have wider peaks than those generated in the narrow peak measurement. The aerosol and sheath flow rates of the nanoDMA were 2 and 10 lpm, respectively. It should be clarified that the particle size distribution classified using the nanoDMA in the wide peak measurement were still narrow due to the limitation of the nanoDMA. A lower sizing resolution either achieved by a higher aerosol-to-sheath flow ratio will cause the nanoDMA out of work due to significant turbulence. A half-mini DMA (Fernández de la Mora and Kozlowski, 2013) with calibrated penetration efficiency and a downstream Faraday cage electrometer (FCE) were used to measure the classified particle size distributions in parallel.

The PSM (Airmodus A11) was calibrated using negatively charged tungsten oxide particles before the test. The experimental setup for the calibration was the same with that used in the narrow peak measurement. The influence of the finite resolution of the Herrmann DMA on the calibrated efficiency curves was negligible. The saturator flow rate of the tested PSM varied from 0.05 to 1.3 lpm. This saturator flow rate range is wider than that of a typical PSM to obtain a complete kernel function curve of 3 nm particles. The maximum background noise of the PSM was approximately 1 No./cm³, which was negligible compared to the usually detected particle concentrations. The detection efficiency is determined as the ratio of the particle number concentrations reported by PSM over the number concentration reported by the electrometer. The detection efficiency curves of the PSM were fitted using a function (Eq. 15) modified from the Chapman-Richards growth curve (Richards, 1959) which fitted better than other tested functions for the tested PSM,

$$\eta = a \times [1 + |b| \times (s - s_{\max})] \times [1 - \exp(-c \times s)]^d, \quad (15)$$

where s_{\max} is the maximum saturator flow rate (1.3 lpm); a , b , c , and d are the fitting parameters. If not specially mentioned, the PSM was fixed at 18 different saturator flow rates when measuring the particle size distributions in this study. This operation in the stepping mode was to avoid the potential uncertainties introduced in the scanning mode. The stability of the particle size distribution was monitored using the reference FCE during the relatively long measuring period.

3.2 Simulation

The performance of the four inversion methods was also studied using Monte Carlo simulations. The detection efficiencies used in the simulations were determined according to the calibrated efficiencies but slightly adjusted towards smoother curves. The uncertainties in practical calibration were neglected in the simulation.

The particle number concentrations detected at different saturator flow rates were simulated using a certain initial particle size distribution. The random error, ε_i , was inserted into the simulated particle concentration, R_i . The random errors were determined experimentally. The relative random errors were larger than the statistical relative errors predicted using Poisson distribution (Iida, 2008; Kuang et al., 2012; Kangasluoma and Kontkanen, 2017) and independent of the particle concentrations at a certain instrumental configuration, indicating that random errors were governed by the fluctuations of the source and/or the instrumental parameters (e.g., flow rate). We used the mean relative random standard deviation observed in the experimental tests, 3.7%, as the representative value. Totally 10 data points were assumed to be collected at each saturator flow rate. Thus, the random errors inserted into the simulated particle concentrations, i.e., the relative standard deviations of the mean particles concentrations, were assumed to be 1.2% ($= 3.7\% / \sqrt{10}$). A relatively large random error of 10% obtained from the ambient measurements was also tested. The Monte Carol simulation was conducted for 10000 times using each inversion method to estimate the accuracy and precision of the recovered particle size distribution indicated by the mean values and the standard deviations of inverted results.

4 Results and discussion

4.1 Sizing accuracy

The inversion methods tested in this study, i.e., the stepwise method, the kernel function method, the H&A method, and the EM algorithm are able to estimate the classified particle diameters when the PSM was measuring nearly monodisperse sub-3 nm particles. When the classified particle diameters were 1.51 nm and 2.41 nm, respectively, all of the four inversion methods can recover single peaks around the classified diameter (Figs 4a, 4b). The size distribution reported by the

stepwise method was the widest because the stepwise method does not account for the resolution of the PSM. Note that the peak diameters reported by the kernel function method and the H&A method were also affected by the selection of the particle size bins. The total particle concentrations obtained via inversion were similar to the number concentration detected by the reference FCE, except for the number concentration of 1.51 nm particles reported by the kernel function method.

None of the four inversion methods could size particles larger than 3 nm with relatively good sizing accuracies. When the classified particle diameter was 3.93 nm, the four inversion methods failed to report narrow peaks with peak diameters approximating 3.93 nm (Fig. 4c). This is because the PSM resolution for particles larger than 3 nm is low, i.e., the resolution was ~ 1.0 when measuring the classified 3.93 nm particles (Fig. 2). The 3.93 nm particles contribute to the signal for 2.17 nm particles when using the stepwise method (inferred from Fig. 1 and Fig. 2). When focusing on the sub-3 nm particle size range, the kernel function method, the H&A method, and the EM algorithm reported nearly no sub-3 nm particles. However, the stepwise method reported a non-negligible amount of sub-3 nm particles with a total number concentration of 1591 No./cm³ due to the low sizing resolution.

We further tested the sizing ability of the four inversion methods using the sum of the recorded particle concentrations when the PSM was measuring 1.51, 2.41, and 3.93 nm particles (Fig. 4d). The kernel function method, the H&A method, and the EM algorithm distinguished the particles with different sizes, and the reconstructed peaks were similar to the corresponding peaks when the PSM was measuring monodisperse particles. The inverted results using the stepwise method was also unaffected by the summation, however, it was difficult to distinguish the isolated peaks from the recovered particle size distribution due to the broadened size distribution.

The size distributions of particles larger than 3 nm could not be successfully retrieved via data inversion because of the low resolution of PSM for these particles, however, it helped to recover sub-3 nm particle size distributions. Most of the reported particle sizes using the kernel function method, the H&A method, and the EM algorithm were larger than 3 nm when the PSM was measuring 3.93 nm particles (Fig. 4c). This estimation of particles larger than 3 nm assured a relatively accurate sizing of sub-3 nm particle size distribution (Fig. 4d). Thus, we recovered the particle size distribution up to 5 nm using different inversion methods but focus only on the sub-3 nm size range.

4.2 Uncertainties using different inversion methods

The stepwise method, the kernel function method, and the H&A method may report false sub-3 nm particles when there are only particles are larger than 3 nm in the input aerosol. A particle size distribution with a peak diameter of 5 nm and nearly no sub-3 nm particles was simulated (Fig. 5a). The detected particle concentrations were assumed to fluctuate with a 1.2% relative standard deviation due to measuring uncertainties (Fig. 5b). The EM algorithm reported nearly no sub-3

1 nm particles except for the smallest size bin at 1.16 nm (Fig. 5c). The expected values of particle concentrations in the
2 bins smaller than 3 nm recovered using the H&A method were near zero, however, false sub-3 nm particle concentrations
3 were occasionally reported (Fig. 5d). Compared to the H&A method, the size distribution recovered using the kernel
4 function method was more unstable, especially in the sub-2 nm size range (Fig. 5e). The simulated uncertainty is the main
5 cause of the false sub-3 nm particle concentrations reported by the H&A method and the kernel function method in Fig.
6 5. When assuming that there is no error in the particle concentration detected by the PSM, the H&A method and the kernel
7 function method report nearly no particles in the sub-3 nm size range. Different from the H&A method and the kernel
8 function method that reported false results due to their instability, the stepwise method reported false particle size
9 distributions when assuming there are no uncertainties (Fig. 5f). This is because the stepwise method assumes a simple
10 one-to-one relationship between the saturator flow rate and the recovered particle diameter instead of accounting for the
11 wide kernel function peaks. For sub-1.5 nm particles, the nonzero mean particle concentration reported by the stepwise
12 method is due to the simulated uncertainties.

13 The false sub-3 nm particle concentrations due to improper inversion methods were tested experimentally. Particles larger
14 than 5 nm were classified using the nanoDMA (Fig. 6a). No sub-3 nm particles were reported using the EM algorithm
15 and the H&A method. On the contrast, the kernel function method and the stepwise method reported approximately 3×10^3
16 particles when the total particle concentration measured using the DMA-FCE system was approximately 2.4×10^4 . Based
17 on both the simulating and experimental results, we conclude that the PSM may report false sub-3 nm particle size
18 distributions when there are actually no sub-3 nm particles because of the uncertainties and the non-ideal data inversion
19 methods, especially the stepwise method. Note that large particles whose detection efficiencies do not vary with the
20 saturator flow rate do not lead to a bias in the recovered sub-3 nm particle concentrations. We examined this theoretical
21 deduction experimentally using a PSM to measure ambient particles existing in the room air and the recorded particle
22 concentration did not significantly vary with the saturator flow rate.

23 The performance of the four inversion methods in the sub-3 nm size range under the influences of larger particles was
24 tested using a bimodal distribution (Fig. 7a). Similar particle size distributions are usually observed in the atmospheric
25 new particle formation events (Jiang et al., 2011) and in flame (Tang et al., 2017). As shown in Fig. 7, the particle size
26 distribution recovered using the EM algorithm had the highest accuracy and the smallest uncertainties among the four
27 methods. The recovered particle size distribution using the EM algorithm had a slightly different shape compared to the
28 initial distribution because the results were trapped in the local optimum. However, the differences between the recovered
29 and the initial size distributions were the smallest. The standard deviations of the size distribution recovered using the
30 H&A method and the kernel function method were relatively large due to the unstable least square method. Because of a

1 better assumption of the initial particle size distribution, the H&A method resulted in smaller uncertainties compared to
 2 the kernel function method, especially in the sub-2 nm size range. The size distribution recovered using the EM algorithm
 3 has higher accuracy and stability compared to both the H&A method and the kernel method because the one-to-one
 4 inversion method does not magnify relative errors.

5 The experimental tests using bimodal distributions agreed with the simulation results. The particles with a peak diameter
 6 at approximately 2.3 nm were classified using the nanoDMA. We added the observed number concentration to those
 7 detected in Fig. 6a (particles larger than 5 nm) to account for the influence of large particles. Unfiltered room air served
 8 as the makeup flow to provide background particles. As shown in Fig. 8, all the four inversion methods recovered the
 9 peak around 2.3 nm, while the results reported by the H&A method and the kernel function method were less smooth
 10 compared to the EM algorithm and the stepwise method.

11 Smoothing the size distribution recovered using the H&A method and the kernel function method into fewer size bins
 12 can reduce the uncertainties. We determined the number of the size bins of the recovered distributions according to the
 13 number of the fixed saturator flow rates. Too many size bins will lead to relatively large uncertainties, however, the
 14 uncertainties can be reduced by sacrificing the resolution, i.e., reporting the size distribution in fewer bins. The size
 15 distributions recovered using the kernel function method were reported in typical 4-6 bins (Lehtipalo et al., 2014). This
 16 was achieved by assuming fewer discrete particle diameters in Eq. 5. Another option is to merge bins into fewer numbers
 17 after inversion rather than assume fewer bins at the beginning. Note that the H&A method cannot assume fewer discrete
 18 size bins at the beginning. Instead, the H&A method assumes an adequate number of size bins to guarantee a relatively
 19 smooth distribution (Eq. 8). As shown in Fig. 9, the standard deviations of the reported size distribution with fewer size
 20 bins were comparatively smaller than the corresponding standard deviations with more size bins shown in Fig. 7. The
 21 H&A method reported size distributions with smaller standard deviations than the kernel function method, and the kernel
 22 function reported in merged size bins had smaller standard deviations than the kernel function method using fewer size
 23 bins at the beginning. This is because approximating the true particle size distribution, which is usually a smooth curve,
 24 with fewer discrete size bins will lead to larger uncertainties. Thus, we suggest merging the recovered particle size
 25 distribution into a few size bins to reduce the uncertainties when using the H&A method and the kernel function method.

26 Relatively large uncertainties were found when recovering sub-1.3 nm particle size distributions. A particle size
 27 distribution with an increasing dN/dd_p as a function of the decreasing particle diameter, which is a typical particle size
 28 distribution observed in the atmospheric new particle formation events (Jiang et al., 2011), was used to test the four
 29 inversion methods (Fig. 10). None of the inversion methods reported a particle size distribution with relatively small
 30 uncertainties comparable to the inverted results shown in Fig. 7c, especially in the sub-1.3 nm size range. Similar to the

results for particles larger than 3 nm, the low resolution of particles smaller than 1.3 nm (Fig. 2) is possibly the cause of the large uncertainties. In addition, incomplete kernel function peaks and the relatively low detection efficiencies of sub-1.3 nm particles may also contribute to the uncertainties (Fig. 1).

The performance of the inversion methods under relatively large random errors was also tested. The relative standard deviation used in the above simulations, 3.7%, was estimated according to laboratory experiments. The relative standard deviations of the recorded particle number concentration obtained from the atmospheric measurement were usually similar to the value obtained in the laboratory, indicating the random errors were governed by instrumental factors. However, relatively large uncertainties in the recorded particle number concentrations were sometimes observed due to the unstable atmospheric aerosol source. Thus, we simulated the performance of the four inversion methods using a relative standard deviation of 10%. It should be clarified that the value 10% only characterizes the random errors of the CPC since it was estimated using the data when the recorded particle number concentration did not vary with the saturator flow rate. Compared to the results in Fig.7 simulated using the same aerosol size distribution, the uncertainties in the recovered particle size distributions using the larger relative standard deviation of 10% was larger (Fig. 10). The EM algorithm still reported smaller uncertainties compared to the H&A method and the kernel function method. Note the expected value of sub-2 nm particle size distribution recovered using the kernel method was close to the input size distribution when the uncertainty was 3.7% (Fig. 7); however, the recovered size distribution in the sub-2 nm size range was non-negligibly overestimated when the uncertainty was 10% (Fig. 10).

4.3 Uncertainties in the scanning mode

The PSM instrumental factors limiting the accuracy of the inversion were also tested. Although using the EM algorithm and the H&A method can reduce the errors of the recovered size distributions compared to the kernel function method and the stepwise method, relatively small measuring uncertainties are still vital to retrieve a particle size distribution with relatively high accuracies. The uncertainties in the scanning mode, for example, is one of the potential sources of the measuring uncertainties. The saturator flow rate of a scanning PSM increases linearly with time in previous studies. However, the relationship between the particle diameters and the saturator flow rates at the kernel function peaks is nonlinear (Fig. 2). The detection efficiencies of particles larger than 1.6 nm vary mainly in the flow rate range from 0.05 to 0.3 lpm while the corresponding scanning time is only 20% of the whole scanning cycle. This nonlinear relationship may result in non-negligible uncertainties in the recovered particle size distributions (Fig. 12). The EM algorithm recovered the single peak when using the particle concentrations recorded in the stepping mode. However, the recovered particle size distribution using the EM algorithm was not a single smooth peak when using data recorded in the scanning mode (Fig. 12). This difference can be illustrated using the raw data. The curves of the particle number concentration

recorded in the stepping mode and the scanning mode are similar to each other and they both appear to be smooth (Fig. 13a). When presenting in the derivative of the particle number concentration with the respect to saturator flow rate, however, the curve corresponding to the stepping mode appeared to be a single peak while the other curve corresponding to the scanning mode seemed to be composed of multiple single peaks (Fig. 13b). Since none of the four inversion methods tested in this study add smoothing constraints when solving the Fredholm integral equation of the first kind, this roughness in the raw data will lead to split peaks in the recovered particle size distribution unless one report the size distribution using only a few size bins.

4.4 Implications on using the PSM

According to the discussion above, we provide the following suggestions on using a PSM to determine particle size distributions:

(a) Particle size range and saturator flow rate range. Complete efficiency curves are preferable to determine the particle size distribution in a certain size range. For example, to reduce the uncertainties in the recovered size distribution of ~3 nm particles, the saturator flow rate in this study was extended from the commonly used 0.1 lpm to 0.05 lpm where the detection efficiency of 3.11 nm particles was almost zero. The detection efficiency curves of particles larger than the maximum concerned diameter should also be calibrated to reduce the influence of large particles on the recovered particle size distribution and total concentration. The PSM can theoretically estimate particle size distributions larger than 3 nm or smaller than 1.3 nm, however, the uncertainties are usually large due to the low resolution and the incomplete detection efficiency curves. The particles whose detection efficiency are constant values in the measuring saturator flow rate range cannot be determined using a PSM and they do not influence the recovered particle size distributions if their concentrations are stable during each scanning cycle.

(b) Scanning scheme. The scanning scheme of the saturator flow rate is suggested to be improved to reduce the measuring uncertainties. The scanning scheme is preferably determined to ensure that the particle diameter corresponding to the saturator flow rate increases linearly with time so that the numbers of the recorded particle number concentration at each saturator flow rate are the same when the recovered particle size increases linearly. A convex function between the saturator flow rate and the scanning time, e.g., an exponentially increasing saturator flow rate, is also better than the linear scanning scheme. Such improvement may require updating both the hardware and the software.

(c) Inversion method. We suggest using the EM algorithm to address the PSM inversion problem because the particle size distributions recovered using the EM algorithm have the best accuracy and stability among the four tested methods. However, considering the relatively high computational expense of the EM algorithm, the H&A method reporting in merged size bins is recommended to be used for preliminary data analysis and for meeting the need of fast inversion, e.g.,

1 real-time display on the instrumental screen. The accuracy of the recovered size distribution is also determined by the
2 uncertainties in the recorded number concentration rather than the inversion method alone. The inversion methods
3 suggested in this study does not necessarily assure an accurate inverted result without properly determined detection
4 efficiencies and an improved scanning scheme.

5 (d) Uncertainties in atmospheric measurement. One should be always aware of the potential uncertainties in the recovered
6 particle size distribution, especially when conducting atmospheric measurement. The reported sub-3 nm particle
7 concentrations may be false results due to systematic and random error, especially when using the stepwise method. The
8 number of the reported size bins should also be carefully limited. For example, the EM algorithm can theoretically provide
9 infinite size bins; however, we suggest reducing the reported size bins to avoid false fluctuations.

10 **5 Conclusions**

11 We tested the performance of four inversion methods to recover particle size distributions from the particle size magnifier
12 data using Monte Carlo simulation and experiments. The four inversion methods are the stepwise method, the kernel
13 function method, the H&A method, and the EM algorithm, respectively. The stepwise method may report false sub-3 nm
14 particle concentrations when there are no sub-3 nm particles in the input aerosol because it does not account for the
15 influence of particles large than 3 nm. The kernel function method and the H&A method may lead to relatively large
16 uncertainties in the recovered particle size distribution because of using the unstable least square method, and they
17 occasionally report false sub-3 nm concentrations due to the large uncertainties. Compared to the kernel function method,
18 the H&A lead to smaller uncertainties while having a similar computation expense. This is because that the H&A method
19 assumes a near continuous size distribution rather than a discrete distribution with limited size bins. One can reduce the
20 uncertainties via merging the particle size distribution reported by the H&A method into fewer size bins. Among the
21 tested inversion methods, the EM algorithm has the highest accuracy and stability. Another advantage of the EM algorithm
22 over the other three methods is that it does not limit the number of the particle size bins. The instrumental factors also
23 limit the accuracy and precision of the recovered particle size distribution. The uncertainties of the recovered size
24 distributions of particle smaller than 1.3 nm or larger than 3 nm may be significant due to the incomplete kernel function
25 curves, the low resolution and/or the low detection efficiency. The measuring uncertainties in the scanning mode may
26 also increase the uncertainties of the recovered size distribution.

27 Based on this study, we suggest that a) the EM algorithm is used to recover the particle size distribution measured by the
28 PSM and the H&A method can be used for preliminary data analysis and for fast inversion purposes; b) the hardware and
29 software of the PSM should be improved to reduce the measuring uncertainties, e.g., via changing the scanning scheme

1 of the saturator flow rate; c) one should carefully distinguish the false inverted results from the true sub-3 nm particles,
2 especially in the sub-2 nm size range and/or when using the stepwise method.

3 **Data availability**

4 The characterizations of the tested PSM are shown in the figures. The Matlab scripts for the inversion methods are
5 available upon request.

6 **Competing interests**

7 The authors declare that they have no conflict of interest.

8 **Acknowledgement**

9 Financial supports from the National Key R&D Program of China (2017YFC0209503), the National Natural Science
10 Foundation of China (21521064 & 41730106), ACTRIS-2 (grant agreement No. 654109), the Academy of Finland
11 (project No. 307331), and Faculty of Science, University of Helsinki, are acknowledged. R. Cai appreciates the support
12 from China Scholarship Council (CSC) for his visit to University of Helsinki.

13 **References**

- 14 Ahonen, L. R., Kangasluoma, J., Lammi, J., Lehtipalo, K., Hämeri, K., Petäjä, T., and Kulmala, M.: First
15 measurements of the number size distribution of 1–2 nm aerosol particles released from manufacturing
16 processes in a cleanroom environment, *Aerosol Science and Technology*, 51, 685-693, 2017.
- 17 Buckley, D. T. and Hogan, C. J.: Determination of the transfer function of an atmospheric pressure drift tube ion
18 mobility spectrometer for nanoparticle measurements, *Analyst*, 142, 1800-1812, 2017.
- 19 Dempster, A. P., Laird, N. M., and Rubin, D. B.: Maximum likelihood from incomplete data via the EM algorithm,
20 *Journal of the Royal Statistical Society. Series B (Methodological)*, 39, 1-38, 1977.
- 21 Do, C. B. and Batzoglou, S.: What is the expectation maximization algorithm?, *Nature Biotechnology*, 26, 897-899,
22 2008.
- 23 Ellis, S. P.: Instability of least square, least absolute deviation and least median of squares linear regression,
24 *Statistical Science*, 13, 337-350, 1998.
- 25 Fernández de la Mora, J. and Kozlowski, J.: Hand-held differential mobility analyzers of high resolution for 1–
26 30nm particles: Design and fabrication considerations, *Journal of Aerosol Science*, 57, 45-53, 2013.
- 27 Ferri, F., Giglio, M., and Perini, U.: Inversion of light scattering data from fractals by the Chahine iterative algorithm,
28 *Applied Optics*, 28, 3074-3082, 1989.
- 29 Flagan, R. C.: On Differential Mobility Analyzer Resolution, *Aerosol Science and Technology*, 30, 556-570, 1999.
- 30 Fuchs, N. A., Stechkina, I. B., and Starosselskii, V. I.: On the determination of particle size distribution in
31 polydisperse aerosols by the diffusion method, *British Journal of Applied Physics*, 13, 280-281, 1962.
- 32 Hagen, D. E. and Alofs, D. J.: Linear inversion method to obtain aerosol size distributions from measurements with
33 a differential mobility analyzer, *Aerosol Science and Technology*, 2, 465-475, 1983.
- 34 Hansen, P. C.: Analysis of discrete ill-posed problems by means of the L-curve, *SIAM Review*, 34, 561-580, 1992.
- 35 Iida, K.: Atmospheric nucleation: Development and application of nanoparticle measurements to assess the roles of
36 ion-induced and neutral processes, PhD, University of Minnesota, Minneapolis, 2008.
- 37 Jiang, J., Zhao, J., Chen, M., Eisele, L. F., Scheckman, J., Williams, J. B., Kuang, C., and McMurry, H. P.: First
38 Measurements of Neutral Atmospheric Cluster and 1-2 nm Particle Number Size Distributions During
39 Nucleation Events, *Aerosol Research Letter*, 45, ii-v, 2011.

- 1 Kandlikar, M. and Ramachandran, G.: Inverse methods for analysing aerosol spectrometer measurements: a critical
2 review, *Journal of Aerosol Science*, 30, 413-437, 1999.
- 3 Kangasluoma, J., Junninen, H., Lehtipalo, K., Mikkilä, J., Vanhanen, J., Attoui, M., Sipilä, M., Worsnop, D.,
4 Kulmala, M., and Petäjä, T.: Remarks on Ion Generation for CPC Detection Efficiency Studies in Sub-3-nm
5 Size Range, *Aerosol Science and Technology*, 47, 556-563, 2013.
- 6 Kangasluoma, J., Attoui, M., Junninen, H., Lehtipalo, K., Samodurov, A., Korhonen, F., Sarnela, N., Schmidt-Ott,
7 A., Worsnop, D., Kulmala, M., and Petäjä, T.: Sizing of neutral sub 3nm tungsten oxide clusters using
8 Airmodus Particle Size Magnifier, *Journal of Aerosol Science*, 87, 53-62, 2015.
- 9 Kangasluoma, J., Samodurov, A., Attoui, M., Franchin, A., Junninen, H., Korhonen, F., Kurtén, T., Vehkamäki, H.,
10 Sipilä, M., Lehtipalo, K., Worsnop, D. R., Petäjä, T., and Kulmala, M.: Heterogeneous Nucleation onto Ions
11 and Neutralized Ions: Insights into Sign-Preference, *The Journal of Physical Chemistry C*, 120, 7444-7450,
12 2016a.
- 13 Kangasluoma, J., Attoui, M., Korhonen, F., Ahonen, L., Siivola, E., and Petäjä, T.: Characterization of a Herrmann-
14 type high-resolution differential mobility analyzer, *Aerosol Science and Technology*, 50, 222-229, 2016b.
- 15 Kangasluoma, J. and Kontkanen, J.: On the sources of uncertainty in the sub-3 nm particle concentration
16 measurement, *Journal of Aerosol Science*, 112, 34-51, 2017.
- 17 Knutson, E. O.: History of Diffusion Batteries in Aerosol Measurements, *Aerosol Science and Technology*, 31, 83-
18 128, 1999.
- 19 Kontkanen, J., Lehtipalo, K., Ahonen, L., Kangasluoma, J., Manninen, H. E., Hakala, J., Rose, C., Sellegri, K., Xiao,
20 S., Wang, L., Qi, X., Nie, W., Ding, A., Yu, H., Lee, S., Kerminen, V.-M., Petäjä, T., and Kulmala, M.:
21 Measurements of sub-3 nm particles using a particle size magnifier in different environments: from clean
22 mountain top to polluted megacities, *Atmospheric Chemistry and Physics*, 17, 2163-2187, 2017.
- 23 Kuang, C., Chen, M., Zhao, J., Smith, J., McMurtry, P. H., and Wang, J.: Size and time-resolved growth rate
24 measurements of 1 to 5 nm freshly formed atmospheric nuclei, *Atmospheric Chemistry and Physics*, 12, 3573-
25 3589, 2012.
- 26 Kulmala, M., Petäjä, T., Nieminen, T., Sipilä, M., Manninen, H. E., Lehtipalo, K., Dal Maso, M., Aalto, P. P.,
27 Junninen, H., Paasonen, P., Riipinen, I., Lehtinen, K. E., Laaksonen, A., and Kerminen, V. M.: Measurement
28 of the nucleation of atmospheric aerosol particles, *Nature protocols*, 7, 1651-1667, 2012.
- 29 Kulmala, M., Kontkanen, J., Junninen, H., Lehtipalo, K., Manninen, H. E., Nieminen, T., Petaja, T., Sipila, M.,
30 Schobesberger, S., Rantala, P., Franchin, A., Jokinen, T., Jarvinen, E., Aijala, M., Kangasluoma, J., Hakala, J.,
31 Aalto, P. P., Paasonen, P., Mikkilä, J., Vanhanen, J., Aalto, J., Hakola, H., Makkonen, U., Ruuskanen, T.,
32 Mauldin, R. L., 3rd, Duplissy, J., Vehkamäki, H., Back, J., Kortelainen, A., Riipinen, I., Kurten, T., Johnston,
33 M. V., Smith, J. N., Ehn, M., Mentel, T. F., Lehtinen, K. E., Laaksonen, A., Kerminen, V. M., and Worsnop,
34 D. R.: Direct observations of atmospheric aerosol nucleation, *Science*, 339, 943-946, 2013.
- 35 Lehtipalo, K., Leppä, J., Kontkanen, J., Kangasluoma, J., Franchin, A., Wimmer, D., Schobesberger, S., Junninen,
36 H., Petäjä, T., Sipilä, M., Mikkilä, J., Vanhanen, J., Worsnop, D. R., and Kulmala, M.: Methods for determining
37 particle size distribution and growth rates between 1 and 3 nm using the Particle Size Magnifier, *Boreal
38 Environment Research*, 19, 215-236, 2014.
- 39 Maher, E. F. and Laird, N. M.: EM algorithm reconstruction of particle size distributions from diffusion battery
40 data, *Journal of Aerosol Science*, 16, 557-570, 1985.
- 41 Markowski, G. R.: Improving Twomey's Algorithm for Inversion of Aerosol Measurement Data, *Aerosol Science
42 and Technology*, 7, 127-141, 1987.
- 43 Nosko, O., Vanhanen, J., and Olofsson, U.: Emission of 1.3–10 nm airborne particles from brake materials, *Aerosol
44 Science and Technology*, 51, 91-96, 2016.
- 45 Onischuk, A. A., Baklanov, A. M., Valiulin, S. V., Moiseenko, P. P., and Mitrochenko, V. G.: Aerosol diffusion
46 battery: The retrieval of particle size distribution with the help of analytical formulas, *Aerosol Science and
47 Technology*, doi: 10.1080/02786826.2017.1387642, 2017. 1-17, 2017.
- 48 Peineke, C., Attoui, M. B., and Schmidt-Ott, A.: Using a glowing wire generator for production of charged,
49 uniformly sized nanoparticles at high concentrations, *Journal of Aerosol Science*, 37, 1651-1661, 2006.
- 50 Raabe, O. G.: A general method for fitting size distributions to multicomponent aerosol data using weighted least-
51 squares, *Environmental Science and Technology*, 12, 1162-1167, 1978.
- 52 Ramachandran, G. and Kandlikar, M.: Bayesian analysis for inversion of aerosol size distribution data, *Journal of
53 Aerosol Science*, 27, 1099-1112, 1996.
- 54 Ramachandran, G. and Cooper, D. W. (Eds.): Size distribution data analysis and presentation, John Wiley & Sons,
55 New York, 2011.
- 56 Richards, F. J.: A flexible growth function for empirical use, *Journal of Experimental Botany*, 10, 290-301, 1959.

1 Schäfer, H., Sternin, E., Stannarius, R., Arndt, M., and Kremer, F.: Novel Approach to the Analysis of Broadband
2 Dielectric Spectra, *Physical Review Letter*, 76, 2177-2180, 1996.

3 Tang, Q., Cai, R., You, X., and Jiang, J.: Nascent soot particle size distributions down to 1 nm from a laminar
4 premixed burner-stabilized stagnation ethylene flame, *Proceedings of the Combustion Institute*, 36, 993-1000,
5 2017.

6 Tikhonov, A. N.: On the solution of ill-posed problems and the method of regularization, *Doklady Akademii Nauk*
7 SSSR, 151, 501-504, 1963.

8 Twomey, S.: Comparison of constarined linear inversion and an iterative nonlinear algorithm allplied to the indirect
9 estimation of particle size distributions, *Journal of Computational Physics*, 18, 188-200, 1975.

10 Ude, S. and de la Mora, J. F.: Molecular monodisperse mobility and mass standards from electrosprays of tetra-
11 alkyl ammonium halides, *Journal of Aerosol Science*, 36, 1224-1237, 2005.

12 Vanhanen, J., Mikkilä, J., Lehtipalo, K., Sipilä, M., Manninen, H. E., Siivola, E., Petäjä, T., and Kulmala, M.:
13 Particle Size Magnifier for Nano-CN Detection, *Aerosol Science and Technology*, 45, 533-542, 2011.

14 Wahba, G.: Practical approximate solutions to linear operator equations when the data are noisy, *SIAM Journal on*
15 *Numerical Analysis*, 14, 651-667, 1977.

16 Winklmayr, W., Wang, H.-C., and John, W.: Adaptation of the Twomey Algorithm to the Inversion of Cascade
17 Impactor Data, *Aerosol Science and Technology*, 13, 322-331, 1990.

18 Wu, J. J., Cooper, D. W., and Miller, R. J.: Evaluation of aerosol deconvolution algorithms for determining
19 submicron particle size distribution with diffusion battery and condensation nucleus counter, *Journal of*
20 *Aerosol Science*, 20, 477-482, 1989.





Figure 1 (a) The fitted detection efficiency curves according to calibration data. (b) The estimated kernel function curves according to the fitted detection efficiencies. The kernel function is equal to the derivative of the detection efficiency with the respect to the saturator flow rate.




Figure 2 The saturator flow rate at kernel function peak and the resolution as functions of the particle diameter. Note that the resolution is defined using the saturator flow rate, however, the horizontal axis is shown in the particle diameter corresponding to the peak saturator flow rate for more straightforward understanding.




Figure 3 The experimental setup to calibration the PSM and test the inversion methods.




Figure 4 The recovered particle size distributions using different inversion methods when measuring monodisperse particles. FCE, SW, kernel, H&A, and EM are short for the Faraday cage electrometer, the stepwise method, the kernel function method, the H&A method, and the expectation-maximization algorithm, respectively. The number concentration detected by the reference FCE and the sum of recovered sub-3 nm particle concentration in each size bin are shown in the text. The size distributions in (d) were recovered using the sum of the recorded number concentrations in (a), (b), and (c), i.e., assuming the PSM was measuring 1.51, 2.41, and 3.93 nm particles simultaneously. The sub-3 nm particle concentrations reported by different inversion methods are summarized in Table 1.




Figure 5 The recovered sub-3 nm particle size distributions simulated using the Monte Carlo method when the detected particles were larger than 3 nm. (a) The assumed true particle size distribution. (b) The simulated particle concentrations recorded by the PSM. The concentrations were assumed to fluctuate due to random errors. The particle size distributions were recovered using (c) the EM algorithm, (d) the H&A method, (e) the kernel function method, and (f) the stepwise method. The error bar represents the standard deviation of the recorded particle concentration or the recovered size distribution, and the shaded area indicates the range determined by three times the standard deviation. The dashed lines represent the inverted results assuming there were no random errors in the recorded particle number concentrations. Note that the scale of the vertical axis in (c-f) is different and the appearing possibility of recorded counts or the recovered size distribution is not uniform in the shaded area.




Figure 6 The experimental testing results of the four inversion methods when the PSM was measuring particles larger than 3 nm. (a) The particle size distribution detected by the reference halfmini DMA-FCE system. (b) The particle concentrations recorded by the PSM. The error bars indicate the standard deviations of the recorded particle concentrations. (c) The recovered particle distributions using different inversion method.




Figure 7 The input and recovered sub-3 nm particle size distributions simulated using the Monte Carlo method. Note the vertical axes in panel (c-f) are not the same.




Figure 8 The experimental testing results of the four inversion methods when the PSM was measuring sub-3 nm particles with the influence of larger particles. The particle number concentrations for inversion and the particle size distribution detected using the DMA-FCE system were the sums of two separate experiments rather than real data obtained in a single experiment.




Figure 9 Comparisons of the inverted results using (a) the H&A method smoothing the particle size distribution via merging size bins; (b) the kernel function method smoothing the particle size distribution via merging size bins; and (c) the kernel function method assuming fewer discrete particle sizes in Eq. 5.




Figure 10 The input and recovered sub-3 nm particle size distributions simulated using the Monte Carlo method when the particle size distribution increases with the decreasing particle diameter.




Figure 11 The recovered particle size distributions simulated using the Monte Carlo method when assuming the relative standard deviation of the recorded particle number concentration is 10%. The reported size bins smaller than 1.3 nm recovered using the kernel function method and the stepwise method are not shown because of the large uncertainties.

1




Figure 12 The recovered particle size distributions using the particle number concentration recorded in (a) the stepping mode and (b) the scanning mode.




Figure 13 (a) The relationship between the recorded particle number concentration and the saturator flow rate in the scanning mode and the stepping mode. (b) The derivative of number concentration with the respect to the saturator flow rate.

1 **Table 1** The inverted particle concentrations (in cm^{-3}) using different inversion methods and the total particle number concentration
2 (in cm^{-3}) recorded by the Faraday cage electrometer when measuring monodisperse particles.

	Diameter of test particles			
	1.51 nm (Fig. 4a)	2.41 nm (Fig. 4a)	3.93 nm (Fig. 4a)	1.51, 2.41, and 3.93 nm (Fig. 4d)
Electrometer	5540	3097	7081	8637
EM algorithm	5528	3243	20.5	8546
H&A method	5426	3027	0	8050
Kernel function method	7562	3497	227	10948
Stepwise method	5910	3179	1591	12035

3