

Direct high-precision radon quantification for interpreting high frequency greenhouse gas measurements

Dafina Kikaj¹, Edward Chung¹, Alan D. Griffiths², Scott D. Chambers², Grant Forster^{3,4}, Angelina Wenger⁵, Penelope Pickers^{3,4}, Chris Rennick¹, Simon O'Doherty⁵, Joseph Pitt⁵, Kieran Stanley⁵, Dickon Young⁵, Leigh S. Fleming^{3,6}, Karina Adcock³, Emmal Safi¹, and Tim Arnold^{7,8}

¹National Physical Laboratory, Teddington, UK

²Australian Nuclear Science and Technology Organisation, Locked Bag 2001, Kirrawee DC NSW 2232, Australia

³Center for Ocean and Atmospheric Sciences, School of Environmental Sciences, University of East Anglia, Norwich, UK

⁴National Centre for Atmospheric Science, University of East Anglia, Norwich, UK

⁵School of Chemistry, University of Bristol, Bristol, UK

⁶Now at: GNS Science, Gracefield, Lower Hutt, 5040, New Zealand

⁷School of GeoSciences, University of Edinburgh, Edinburgh, UK

⁸Department of Physical Geography and Ecosystem Sciences, Lund University, Lund, Sweden

Correspondence: Dafina Kikaj (dafina.kikaj@npl.co.uk)

Abstract. We present a protocol to improve confidence in reported radon activity concentrations, facilitating direct site-to-site comparisons and integration with co-located greenhouse gas (GHG) measurements within a network of three independently managed observatories in the UK. Translating spot measurements of atmospheric GHG amount fractions into regional flux estimates ('top-down' analysis) is usually performed with atmospheric transport models (ATM), which calculate the sensitivity of regional emissions to changes in observed GHGs at a finite number of locations. However, the uncertainty of regional emissions is closely linked to ATM uncertainties. Radon, emitted naturally from the land surface, can be used as a tracer of atmospheric transport and mixing to independently evaluate the performance of such models. To accomplish this, the radon measurements need to have a comparable precision to the GHGs at the modelled temporal resolution. ANSTO dual-flow-loop two-filter radon detectors provide output every 30 minutes. The measurement accuracy at this temporal resolution depends on the characterisation and removal of instrumental background, the calibration procedure, and response time correction. Consequently, unless these steps are standardised, measurement precision may differ between sites. Here we describe standardised approaches regarding 1) instrument maintenance, 2) quality control of the raw data stream, 3) determination and removal of the instrumental background, 4) calibration methods and 5) response time correction (by deconvolution). Furthermore, we assign uncertainties for each reported 30-minute radon estimate (assuming these steps have been followed), and validate the final result through comparison of diurnal and sub-diurnal radon characteristics with co-located GHG measurements. While derived for a network of UK observatories, the proposed standardised protocol could be equally applied to two-filter dual-flow-loop radon observations across larger networks, such as the Integrated Carbon Observation System (ICOS) or the Global Atmosphere Watch (GAW) baseline network.

1 Introduction

20 The Paris Agreement aims to keep this century's mean global temperature rise well below 2 °C and pursue efforts to limit it to 1.5 °C above pre-industrial levels. Meeting this goal requires better understanding of GHG emissions to enable the most efficient mitigation policies to be implemented. Current GHG emission information is dominated by "bottom-up" (prior) estimates derived from aggregated activity data, emission factors and facility-level measurements (from local to country scale) that rely on reported data and knowledge of natural systems (e.g. Ciais et al., 2014; Gurney et al., 2016; Nisbet and Weiss, 25 2010). Since there can be large uncertainties associated with the spatial and temporal variability of these emission factors across sectors, as well as potential biases from unaccounted sources, especially for non-CO₂ GHGs, it is prudent to seek independent verification of the resulting emission estimates. To this end, a distributed network of precise, high frequency, in situ GHG observations can provide opportunities for independent "top-down" verification of GHG emissions estimate.

In recent decades many GHG monitoring stations have been developed throughout Europe. The Integrated Carbon Observa- 30 tion System (ICOS) (<https://www.icos-cp.eu/>, last access: 24 March 2024) constitutes Europe's primary research infrastructure for standardized, traceable, high-precision observations of atmospheric GHG amount fractions. This atmospheric monitoring network includes 46 stations across 16 European countries (Yver Kwok et al., 2015; Yver-Kwok et al., 2021) (<https://www.icos-cp.eu/observations/atmosphere/stations>, last access: 25 March 2024). The corresponding UK GHG network is UK DECC (UK Deriving Emissions related to Climate Change) consisting of five stations (Figure 1): Mace Head (MHD), a World Meteorolog- 35 ical Organisation (WMO) Global Atmosphere Watch (GAW) baseline station, Tacolneston (TAC), Ridge Hill (RGL), Bilsdale (BSD), and Heathfield (HFD), each of which having at least one inlet 90 m or more above ground level (a.g.l.) (Stanley et al., 2018; Stavert et al., 2019).

The most commonly used top-down method for making GHG emissions estimate is through the use of inverse modelling, where high-quality GHG measurements are combined with atmospheric transport models (ATMs) and prior information to 40 make optimal emissions estimate (Arnold et al., 2018; Bergamaschi et al., 2015, 2018; Brown et al., 2023; Ganesan et al., 2015; Lunt et al., 2021; Manning et al., 2011, 2021). Another method is the Radon Tracer Method (RTM), which utilizes simultaneous, co-located observations of ²²²Rn (hereafter radon) and a GHG, in combination with an estimated radon source function. Different implementations of this approach allow either local or regional-scale GHG emissions estimate to be made from the same fetch region influencing the radon observations (e.g. Biraud et al., 2000; Grossi et al., 2018; Hirsch, 2007; Levin, 45 1987; Levin et al., 2021; van der Laan et al., 2014; Vogel et al., 2012; Wada et al., 2013).

Despite recent improvements in the spatio-temporal density of observations, and excellent quality of GHG measurements (relative uncertainties often <0.1 %), as well as the mathematical elegance of ATMs (e.g. Baker et al., 2006; Dentener et al., 1999; Tolk et al., 2008; Zhang et al., 2021) large uncertainties remain in total annual top-down GHG emissions estimate (e.g., ~10 % for the UK N₂O emission estimate; UK's National Inventory Report to the United Nations Framework Convection on 50 Climate Change 2022). A key contributor to the overall uncertainty in top-down inverse model estimates of GHG emissions is the ATMs themselves. The challenge of quantifying ATM uncertainty is evident in tasks such as boundary layer height estimation and parametrisation of meteorological variables, where errors are related to the resolution of the model (e.g. Geels

et al., 2007; Gerbig et al., 2008; Liu et al., 2011; Munassar et al., 2023; Tolk et al., 2008). As yet, no optimal method exists to evaluate the discrepancies between *a priori* and *a posteriori* emissions estimate (bias). Until it is possible to accurately quantify an ATM's uncertainty, full realization of the potential offered by high-quality atmospheric measurements from a comprehensive tower network cannot be achieved. This is a crucial step for improving national inventories and developing policy that the international community should have to hand while strengthening the 2015 Paris Agreement.

To this end, measurements of the naturally occurring, passive tracer radon could provide a means of evaluating ATM performance. Moreover, subject to the measurement location and sampling height, among other things, radon observations can be a valuable tool for atmospheric baseline monitoring (e.g. Chambers et al., 2016), evaluating the performance of regional or global chemical transport models (e.g. Chambers et al., 2019a; Zhang et al., 2021) or characterizing the atmospheric mixing state (Chambers et al., 2019b; Kikaj et al., 2023; Perrino et al., 2001; Williams et al., 2016). Consequently, efforts to broaden the international radon monitoring network and harmonise the resulting measurements not only stand to improve GHG emissions estimate via atmospheric inversion studies, but also provide a second independent top-down method to estimate local- to regional-scale GHG emissions via the RTM, as well as other research opportunities.

Radon is the gaseous decay product of ^{226}Ra (radium), a member of the ^{238}U (uranium) decay chain, which is ubiquitous all over the Earth's crust. When emitted into the atmosphere, radon experiences the same atmospheric transport and mixing as all other gases released near surface. Being an inert gas, radon (^{222}Rn) does not chemically react with any atmospheric constituents and its low solubility makes it resistant to dry and wet deposition, leaving radioactive decay (half-life of 3.82 days) as its sole atmospheric sink. Its half-life, conveniently between the timescales of diurnal and synoptic atmospheric processes, is ideal for characterizing a wide range of meteorological phenomena (Galmarini, 2006; Kikaj et al., 2019; Williams et al., 2013; Zahorowski et al., 2004). It is therefore considered a powerful and convenient tracer at meso, synoptic and global scales for improving, testing and validating atmospheric models (Chambers et al., 2015, 2019b; Israël et al., 1966; Jacob et al., 1997; Taguchi et al., 2002; Zhang et al., 2021).

Since its discovery in 1900, radon's unique physical characteristics have led to its use in studies of vertical mixing and air mass history (Eve, 1908; Wigand and Wenk, 1928; Wright and Smith, 1915). Early studies employed a variety of discrete measurement techniques but were often lacking in sensitivity or temporal resolution. Most significant progress in utilising radon as a relative tracer for vertical mixing and transport near the Earth's surface has been achieved since the 1960s, mainly driven by advancements in continuous measurement techniques. Initially, public health (indoor) applications dominated instrument development, but the large indoor-to-outdoor gradient in radon activity concentrations (henceforth radon concentrations) limited the utility of these instruments in the outdoor environmental atmosphere. The first semi-continuous radon detector was developed in the mid-1960s (Taylor and Lucas, 1967). While suitable for near-surface inland measurements, this type of detector was not sufficiently sensitive for measurements at coastal or island sites. The capability to measure radon concentrations typical of the remote marine atmosphere began to emerge post-1970 (Lambert et al., 1970; Polian et al., 1986; Pereira and Da Silva, 1989; Levin, 1987). More recently still, refinement of the original two-filter radon detector (Thomas and Leclare, 1970) by Whittlestone and Zahorowski (1998) greatly improved both the sensitivity and temporal resolution of radon measurements, better aligning them with advances in GHG measurements and modelling resolution. This growing collection of

one- and two-filter radon monitors constituted the first of the “research grade” instruments. Following these developments, the popularity of radon increased as a quantitative tracer in atmospheric modelling (Chevallard et al., 2002; Dentener et al., 1999; 90 Jacob et al., 1997; Hirao et al., 2008; Mahowald et al., 1995; Zahorowski et al., 2004; Zhang et al., 2021) and estimation of GHG fluxes on local to regional scale by the RTM (Biraud et al., 2000; Grossi et al., 2018; Levin, 1987; Levin et al., 2021; van der Laan et al., 2009, 2014).

Contemporary research-grade radon monitors are based on three fundamentally different measurement techniques: (i) indirect one filter α - or β - activity detectors, which directly filter ambient aerosol-bound radon progeny from the atmosphere and count them, assuming equilibrium between atmospheric radon and its progeny (Biraud et al., 2000; Levin et al., 2002; 95 Levin, 1987; Polian et al., 1986); (ii) direct two filter detectors that first remove ambient radon progeny, before filtering-out and counting new unattached radon progeny formed inside a large measurement volume under controlled conditions (Chambers et al., 2022; Griffiths et al., 2016; Whittlestone and Zahorowski, 1998), and (iii) direct electrostatic deposition monitors, which also remove ambient progeny and allow new progeny to form inside a small measurement volume, but deposit these progeny 100 electrostatically on a detector (Grossi et al., 2012; Pereira and Da Silva, 1989; Wada et al., 2013).

Continuous, long-term atmospheric radon measurements are currently performed worldwide using the three principles of measurement mentioned above. Maximising the value and utility of such large datasets across a range of applications requires a traceability chain for calibrations and standardised data processing techniques appropriate to each type of detector. Although, there have already been some efforts to compare and harmonise radon measurements across the existing eclectic global network (Grossi et al., 2020; Xia et al., 2010; Schmithüsen et al., 2017) more attention needs to be given to preparation of a 105 standardised protocol for retrieving the highest-quality, most directly comparable, atmospheric radon datasets from each kind of contributing instrument. Due to the distinct measurement principles of each instrument, tailored approaches are necessary to maximise consistency and comparability of datasets. For instance, indirect one-filter detectors require corrections for tube loss, equilibrium (for inlets below 80–100 m a.g.l.), and exclusion of foggy/rainy conditions. While two-filter detectors are 110 highly sensitive and independent of tube length, measurement height or weather conditions, the larger models (700 L and 1500 L) can have a 4–8 % uncertainty on individual field calibrations (unless a transfer standard is used) and require response time correction. Meanwhile, electrostatic deposition monitors need to dry their sample air (and/or correct for water vapor), remove or correct for thoron (^{220}Rn). Therefore, to maximise consistency and comparability across various instruments, it is essential to establish a standardized processing procedure for each instrument type. This instrument-specific standardized procedure 115 should be applicable to any atmospheric station measuring radon concentration with that type of instrument, and would enable optimal utilisation of radon measurements by the atmospheric composition research community, particularly in studies verifying GHG emission estimates.

To this end, here we present a new protocol for processing measurements made by the fastest (30-minute temporal resolution), most sensitive (detection limit $\sim 0.025 \text{ Bq m}^{-3}$), and most widely used radon detectors within global and European 120 atmospheric monitoring networks - the 1500 L “two-filter dual flow-loop” detector, developed by the Australian Nuclear Science and Technology Organisation (ANSTO). In the last 28 years, 50 two-filter radon detectors have been part of campaigns or global and European atmospheric monitoring networks (39 of which are still operational), 11 (4) of which are part of the

125 ICOS (UK DECC) network. Compared to indirect detectors, two-filter detectors provide a measure of radon concentration that is independent of height above ground, distance from land, meteorological conditions (e.g. fog/rain), fetch conditions, ambient aerosol loading, length or type of sampling tube. Consequently, their calibration traceability is more readily achievable under a wide range of measurement conditions (Chambers et al., 2022).

130 This study utilizes one year (September 2020–August 2021) of radon measurements by 1500 L two-filter detectors at the three UK sites with contrasting sample inlet heights: TAC, HFD (UK DECC sites), and Weybourne Atmospheric Observatory (WAO, a UK ICOS and affiliated DECC site). The specific objectives are to: (i) outline the expected maintenance protocol for these detectors, (ii) outline a proposed standard processing protocol for near real time data use, including calibration, response time correction (Griffiths et al., 2016), standard temperature and pressure (STP) correction, and, optionally, correcting output to dry-air amount fractions; (iii) validate the timing of response time corrected radon concentrations using well-defined calibration events; and (iv) assess the precision of the resulting radon signal by comparing it with high resolution GHG (CO₂, CH₄, and N₂O) amount fractions measurements aggregated to 60-minute values.

135 2 Measurement sites and instrumentation

2.1 Measurement sites

140 This study focuses on atmospheric radon concentration and GHG (CO₂, CH₄, and N₂O) amount fraction measurements made at three sites of the UK DECC network with contrasting inlet heights (TAC, HFD, and WAO; Figure 1). Measurements at RGL (51.998° N, 2.540° W) were excluded due to the limited calibration and background measurement history within this study's time frame. Measurements at MHD were also excluded since radon concentrations at this station are conducted with a one-filter detector (Biraud et al., 2000). Each station in the UK DECC network measures at least CO₂, CH₄, N₂O and sulfur hexafluoride (SF₆). However, some also measure carbon monoxide (CO), stable isotopic ratios ($\delta^{13}\text{C}(\text{CH}_4)$, $\delta^2\text{H}(\text{CH}_4)$), radiocarbon in atmospheric CO₂ ($\Delta^{14}\text{CO}_2$), and the oxygen/nitrogen (O₂/N₂) ratio.

145 For the results here, measurements of radon concentration, CO₂, CH₄, and N₂O amount fractions have been aggregated to hourly temporal resolution and reported in **Local Solar Time (LST; equivalent to Universal Time Coordinated (UTC)** in these locations). The Northern Hemisphere seasonal convention has been adopted (i.e., autumn: September–November; winter: December–February; spring: March–May; summer: June–August).

2.1.1 Tacolneston (TAC)

150 The TAC tall tower (52.518° N, 1.139° E; 56 m above sea level (a.s.l.)) is situated southwest of Norwich, 28 km east of Thetford, in Norfolk. Sampling inlets are arranged at three heights: 54, 100 and 185 m a.g.l. Since 2012, measurements of CO₂, CH₄, N₂O, CO, and SF₆ amount fractions have been taken at all heights. In 2020, radon concentration started being sampled from 175 m a.g.l. Additional technical details regarding the tower setup can be accessed in Stanley et al. (2018).




Figure 1. Geographical position of UK DECC stations measuring radon activity concentration: TAC, HFD, RGL, and MHD, along with affiliated WAO - an ICOS site. *Note: measurements from MHD and RGL, highlighted in grey, are not considered in this study.*

As well as being part of the UK DECC network, TAC is part of the Advanced Global Atmospheric Gases and Experiment (AGAGE) network and is a WMO GAW regional site.

155 2.1.2 Heathfield (HFD)

The HFD tall tower (50.977° N, 0.231° E; 157 m a.s.l.) is situated in southeast England, 20 km from the coast, surrounded by woodland and agricultural green space. Measurements at this site are being conducted from an existing telecommunication tower. Sampling began in January 2014, and measurements of key GHGs (CO₂, CH₄, N₂O, and SF₆) are being made from two sampling inlet heights (50 and 100 m a.g.l.). Atmospheric radon measurements were introduced in 2020, with an independent
 160 inlet at 100 m a.g.l. Further information on technical details of the tower setup can be found in Stavert et al. (2019).

HFD is a part of the UK DECC network and is also a WMO GAW regional site. HFD is considered to be a background site of the UK DECC network as the predominant southwesterlies experience little land fetch prior to reaching HFD from the Atlantic Ocean (see Figure 1). However, it can also experience high pollution events since it is relatively close to the conurbation Royal Tunbridge Wells (17 km north-northeast), greater London (40 km north-northeast), and continental Europe (south-west).

165 2.1.3 Weybourne Atmospheric Observatory (WAO)

The WAO (52.951° N, 1.122° E; 17 m a.s.l.) is situated on the north Norfolk coast, approximately 35 km north-northwest of Norwich, 170 km northeast of London and 200 km east of Birmingham. WAO is an ICOS site, a regional WMO GAW site, and is also an affiliated UK DECC site. WAO was established in 1992 (Penkett et al., 1999) and a wide array of atmospheric gas species (GHG amount fractions, stable isotopic ratio, reactive gases, as well as radon since March 2018) are measured there from a sampling inlet at 10 m a.g.l. Due to its location, WAO receives a variety of air masses from a range of sources including well-mixed background air (Atlantic, Arctic, North Sea) and polluted air (European, UK) (Adcock et al., 2023; Fleming et al., 2012; Forster et al., 2012).

2.2 Radon instrument: 1500 L dual-flow-loop two-filter

2.2.1 Operating principle

175 Atmospheric radon concentration is measured at all three sites (HFD, TAC, and WAO) using 1500 L dual-flow-loop two-filter radon detectors, designed and built by ANSTO, which provide half-hourly, high accurately and precision measurements. The principle of operation is described in detail elsewhere (Chambers et al., 2022; Griffiths et al., 2016; Thomas and Leclare, 1970; Whittlestone and Zahorowski, 1998) and is only summarised here. The detector relies on gross α -counting, making the signal sensitive to other radon isotopes (e.g., ^{220}Rn , half-life of 55.6 s; and actinon: ^{219}Rn , half-life of 4 s) as well. To eliminate contributions from unwanted radon isotopes (of which the longest lived is ^{220}Rn), this system includes a "thoron delay volume" prior to the first filter, which acts to delay the sampled air for ~ 5 minutes, allowing time for all short-lived radon isotopes to decay to their aerosol progeny. Following this, the sampled air is filtered (by the "primary filter") to remove the progeny of all radon isotopes and any ambient aerosols before it passes through to the main delay chamber, where a portion of the sampled ambient ^{222}Rn decays under controlled conditions to produce unattached aerosol progeny. These new unattached progeny (particularly the short-lived α -emitters ^{218}Po and ^{214}Po) are then efficiently collected on a 20 μm stainless steel mesh (the second filter). The instrument then reports the number of α -decays counted each 30 minutes using silver activated zinc-sulphide (ZnS(Ag)) scintillation material coupled to a photomultiplier (referred to as the "measurement head"). Output from the photomultiplier is amplified and fed into a discriminator. Total counts above a threshold of 0.5 V are recorded as LLD (lower level of discrimination) and total counts above a threshold of 1.0 V are recorded as ULD (upper level of discrimination). It has been empirically determined that ULD counts essentially represent different forms of noise, so it is the number of counts that lie within 0.5–1.0 V pulse-height window that are used to calculate the activity concentration of radon (in Bq m^{-3}) is calculated. The timestamp associated with a count represents the end of the measurement period.

2.2.2 Instrument maintenance

Although ANSTO two-filter radon monitors are designed to require minimal maintenance, a degree of periodic maintenance is required to minimise ongoing operational costs and ensure consistent optimal performance, a pre-requisite for effectively

harmonising measurements across a network. Most crucial to ongoing performance is the detector's measurement head, which contains the second filter and a plastic sheet impregnated with ZnS(Ag) powder. These materials should be replenished every 5 years. The second filter will slowly accumulate lead (^{210}Pb , half-life of 22.3 years) and can not be cleaned. If the background becomes too high (e.g., $> 8\text{--}10 \text{ counts min}^{-1}$), then the detection limit will deteriorate. The integrity of the ZnS(Ag) powder will also deteriorate over time (faster in very humid environments) and progressively reduce the detector's sensitivity to radon (typically a change of 0.5–1.5 % per annum (p.a.)). If the detector is in a high vibration environment, there should be an annual check that the measurement head is still properly seated in the central pipe (following instructions in the detector's commissioning document). Likewise, if the detector is moved vigorously with the measurement head still inside, the seating of the head in the central pipe should be checked.

The next most important maintenance consideration is the detector's calibration system. If a pump is used to flush the radon source (rather than compressed gas), the stability of the delivery flow rate ($0.10\text{--}0.15 \text{ L min}^{-1}$) should be checked every 3–6 months or radon delivery during calibrations may become inconsistent. The desiccant tube attached to the calibration system inlet should be checked and refilled every 3 months to maintain consistent humidity levels. Fluctuations in humidity within the source capsule could potentially affect the radon emanation rate. Conversely, compressed gas calibration systems only require a 2-yearly replacement of the gas bottle for maintenance.

To protect the radon detector's sampling pump and extend the life of the primary filter, it is essential to prevent dust from passing too far through the sampling line. Typically, an easily accessible and cost-effective coarse aerosol filter is installed upstream of the pump. Depending on the expected aerosol loading at each site, this pre-filter should be inspected and/or replaced every 6–12 months.

The detector should be checked for leaks annually, with the leak rate not exceeding 2 L min^{-1} . To prevent near-surface radon-rich air entering the detection volume due to potential small leaks, it's crucial to maintain the operating overpressure of the detector's main (1500 L) delay volume between $1\text{--}2 \text{ hPa}$. Note that if a long exhaust line is fitted to the detector the associated flow impedance may increase the overpressure to between $2\text{--}3 \text{ hPa}$. The inlet line (from the base of the sampling tower to the inlet of the detector) should also be checked for leaks annually.

The internal clock of the detector's data logger should be synchronised to the networked operating computer quarterly and the logger's internal battery replaced every 5 years. All moving parts of the detector should be replaced every 10 years to avoid mechanical failure, and all electrical components (particularly power supplies) should be replaced every 10 years to prevent electrical noise developing.

2.2.3 Instrument calibration

ANSTO two-filter detectors are too large to be moved periodically and traceably calibrated in a controlled climate chamber, and their high sampling rate (90 L min^{-1}) makes it financially and logistically impractical to attempt regular, traceable calibrations directly in situ (which would require a 90 L min^{-1} flow of radon-free air for around 8 hours; either through a filtration system or a large bank of gas cylinders). The ideal calibration approach would be to transfer a traceable calibration to the operating detector using a mobile calibration transfer device (Chambers et al. 2022; Rottger et al 2023). While few such devices are

230 currently available, inquiries about obtaining one can be sent to radon@ansto.gov.au. The compromise usually adopted is to conduct approximate in situ calibrations using a portable radon source while the instrument continues to sample ambient air. The procedure for a single calibration event is described below.

All ANSTO two-filter radon detectors in this study are calibrated using passive Pylon 2000A ^{226}Ra sources ~ 49 kBq (Pylon Electronics, <https://pylonelectronics-radon.com/radioactive-sources/>, last access: 24 March 2024; the source strength at each site is reported in Table A1). The timing of calibrations, duration of calibrations and source flushing times are all user-defined and can slightly change from site to site.

Prior to initiating a calibration, the ^{226}Ra source should be well flushed, with the exhaust directed to the outside ambient air at a point well removed from the detector sampling location. The optimal flushing time for each calibration setup is assessed by the shape of the calibration curve. The curve should rise monotonically to a near-constant concentration after ~ 5 hours. If the curve rises steeply, overshoots, and then begins to decrease again, the source was not sufficiently flushed. The flushing time should be determined empirically for each installation and will depend on factors such as the source strength, the flushing flow rate, and the time since the source was last flushed. The flushing flow rate is usually lower ($0.08\text{--}0.15$ L min^{-1}) if the source is being flushed with ambient air (to minimise the amount of ambient ^{222}Rn and ^{220}Rn introduced to the system) but can be higher ($0.15\text{--}0.25$ L min^{-1}) if being flushed with dry, radon-free air (to improve the consistency of radon delivery). A flushing period between 5–10 hours is usually sufficient. Once the initial flushing is complete, a calibration is then performed by continuing to pass air through the source, but this time directed into the detector’s sampling airstream, for a period of 5 hours while the detector continues to operate normally (see Figure 2). After injection finishes, it can take up to 6 hours for the radon concentration inside the detector to return to ambient values.




Figure 2. Example calibration peak resulting from a 5-hour injection and net calibration peak magnitude derived from linearly estimated ambient radon concentration at the time of peak counts.

Once the calibration injection has been performed the calibration coefficient, c_{cal} (counts s^{-1} (Bq m^{-3}) $^{-1}$), is calculated through the following equation:

$$c_{cal} = \frac{(LLD_{peak} - LLD_{peak,a})}{1800} \times \frac{F_{ex}}{d_{source}} \times s \quad (1)$$

where LLD_{peak} is the count recorded at the 5-hour injection, and $LLD_{peak,a}$ is the estimated ambient count (at the 5-hour peak counts), F_{ex} ($m^3 s^{-1}$) is the sampling flow rate, d_{source} ($Bq s^{-1}$) is the radon delivery rate of the ^{226}Ra calibration source, and s is a dimensionless scaling factor.

255 The scaling factor is required to account for the fact that after only 5 hours of injection from the source, the radon concentration within the detector will not have completely come to equilibrium, due to its logarithmic growth curve. Based on a model of the detector response (Griffiths et al., 2016) after 5 hours of injection into a 1500 L radon detector sampling at $90 L min^{-1}$ the concentration of radon inside the detector would have reached $\sim 99.3\%$ of the equilibrium value. This leads to scaling factor of 1.007 (reciprocal of ~ 99.3) for a 1500 L detector. A Python notebook that provides an analytical solution to the model
260 equations and can be used to calculate the scaling factor is available at <https://github.com/anstoradonlab/radcalstim>.

Assuming that the calibration unit is functioning reliably, the largest source of uncertainty in the field calibration process is in the estimation of $LLD_{peak,a}$. Typically, an assumption is made that ambient radon concentrations change little, and linearly, over the duration of the calibration event (10–11 hours; yellow line, Figure 2). However, the accuracy of this assumption is influenced by many factors, including timing of the calibration injection within a diurnal cycle, ambient wind speed during
265 the calibration event, air mass fetch conditions, and day length (see Figure 7a in Chambers et al., 2022). Consequently, at flat inland sites calibrations are best performed during windy conditions and the source injection should be timed to finish around 13:00–14:00 LST, when the boundary layer is deepest and most well-mixed. For coastal or island sites calibrations are best performed under windy conditions with oceanic fetch. Under oceanic fetch conditions the calibration injection duration can be increased to 6 hours to reduce the magnitude of the required scaling factor, s . At high mountain sites calibrations are best
270 conducted at night under katabatic flow conditions. Either calibrations can be initiated remotely during suitable conditions, or they can be set on a regular schedule, and events occurring during non-ideal conditions can be excluded.

To minimise relative uncertainty introduced by the $LLD_{peak,a}$ estimation process, the detectors are usually calibrated at a radon concentration that is at least an order of magnitude greater than the expected annual maximum ambient radon concentration at the site. Despite being calibrated at relatively high radon concentrations, the resulting calibrations have been proven
275 to be quite linear down to very low radon concentrations (Röttger et al., 2023).

To this end, consistent, application specific calibration approaches need to be agreed upon and formalised (a key goal of this study) rather than users at different sites simply applying each monthly calibration coefficient. As previously mentioned, if a calibration transfer device is available (Chambers et al., 2022; Röttger et al., 2023) then a traceable calibration can be transferred to an operating 1500 L detector in situ, over a period of around 2 weeks, without the need for approximate monthly
280 calibrations. In this case, it would only be necessary to calibrate the detector once per year to characterise the slow change in sensitivity over the 5-year period until the measurement head is refreshed. If one portable calibration transfer device was allocated to a network of five 1500 L two-filter radon detectors, the cost would be less than buying individual calibration devices for the 5 large detectors.

In the absence of a calibration transfer device, the next most accurate calibration approach (as described in Chambers et al. 2022) is to develop a linear calibration model for the 5-year period between detector head replacements, since the gradual
285 degradation of the ZnS(Ag) scintillation material is the primary cause of changing detector sensitivity. However, this calibration

method can only be applied retrospectively. While the level of calibration accuracy provided by this approach is necessary for deriving consistent vertical radon gradient measurements from tall towers, an alternative calibration approach (with a slightly increased uncertainty) is necessary if the observed radon concentrations need to be used in near real time (described in Section 3.2 and 3.3). Regarding gradient measurements, during the day, when mixing in the atmospheric boundary layer is strongest, radon gradients over the lowest 50 to 100 m of the atmosphere can be as low as 0.1-0.2 Bq m⁻³ (e.g. Chambers et al., 2011). The response time of two filter radon detectors is too slow for a single detector to be multiplexed for multi-height (gradient or profile) measurements. This means that separate (independently calibrated) detectors are required to measure concentrations at each height. Since daytime radon concentrations over land in the surface layer are typically 1-3 Bq m⁻³, and the measurement uncertainty of ANSTO 1500 L detectors is <~10 % for radon concentration (see Grossi et al., 2020), it is usually possible to reliably determine such gradients when detectors are appropriately calibrated.

2.2.4 Instrumental background

The instrumental background, LLD_{bg} (counts per 30 minutes), of ANSTO two-filter detectors arises from various contributing factors, such as: (i) cosmic radiation, (ii) natural radioactivity of surrounding rocks, soils or building materials, (iii) accumulation of ²¹⁰Pb as well as intrinsic background count rate of the photomultiplier caused by other effects (e.g., photons (Wright, 2017)) on the detector's second filter, and (iv) self-generation of radon (by trace amounts of ²²⁶Ra in the detector building materials). The first two factors are small, site specific and relatively constant. ²¹⁰Pb accumulation gives rise to an increasing α -count (due to subsequent ²¹⁰Po decay). Self-generation of radon inside a detector is also constant (due to the 1600-year half-life of ²²⁶Ra), typically small, and varies from build-to-build of each detector. Considered over multiple years, the detector's background count increases approximately linearly.

Ideally, the background should be determined while the detector is operating normally, sampling radon-free air at 90 L min⁻¹ for a period of at least 10–12 hours. However, the necessary supply of radon-free air for regular tests of this kind is logistically and financially impractical. The compromise for field LLD_{bg} is to simply shut the sampling system down for a 24-hour period. It is advised to conduct these checks every two to three months. Background measurements are conducted by deactivating blowers in both the external and internal flow loops, as well as closing the detector's inlet solenoid valve for 24 hours. This process is divided into three stages:

1. **Decay (5.5 hours):** This 5.5 hours period marks the decay of the short-lived radon progeny on the detector's second filter below detection limits within 5–6 hours of the detector shutdown.
2. **Background (18.5 hours):** The count reading stabilises (with a degree of uncertainty) to a constant background level.
3. **Recovery (1–2 hours):** Upon reactivating the blowers and detector's inlet solenoid valve is opened, the instrument undergoes several 30-minute measurement cycles (1–2 hours) to readjust itself and return to the ambient levels

During a background check the detector's inlet is blocked to prevent flow through the detector arising from venturi effects across the inlet line (near the top of the sampling tower). However, the detector's exhaust valve is left open, making it

possible for back diffusion of radon to occur into the detector. This is usually only a concern at sites where nocturnal radon concentrations at the detector's location are high. Closing both the inlet and exhaust valves of the detector during a background measurement is not advisable unless the detector is in a temperature-controlled environment or equipped with a pressure relief mechanism. Diurnal temperature variations could lead to pressure fluctuations within the detector, potentially causing leaks. The inlet valve is closed in preference to the exhaust valve during a background check to prevent over-pressuring the detector if the powerful external flow loop blower is accidentally restarted before the exhaust valve is opened.

If the 18-hours background data in step 2 above is observed to gradually decrease, rather than being approximately constant, ^{220}Rn contamination of the second filter (in the measurement head) is likely. This is indicative of a leak (e.g., in the sampling line or the detector), or an accumulation of ^{224}Ra containing dust in the detector's thoron delay volume.

2.3 Greenhouse Gas (GHG) instruments

At HFD, continuous, high frequency (0.2 Hz) CO_2 and CH_4 measurements are made using a G2401 cavity ring-down spectrometer (CRDS; Picarro Inc., USA), while (0.4 Hz) N_2O measurements are made using G5310 CRDS. At TAC, (0.3 Hz) CO_2 and CH_4 measurements are made using a G2301 CRDS, while (1 Hz) N_2O measurements are made using an off-axis integrated cavity output spectrometer (OA-ICOS; Los Gatos Research Inc., USA). Sampling occurs alternately at different inlet heights along the tower, resulting in measurements from various heights not being simultaneous. For instance, at HFD air is sampled for about 20 min at 50 m a.g.l., followed by another 40 min of sampling at 100 m a.g.l. with a minute of flushing in between to avoid contributions from the previous level. To address this height-switching during sampling, measurements are linearly interpolated to create a continuous hourly time series instead of straightforwardly averaging over an hour. Data are corrected for daily linear instrumental drift using standard gases (natural composition) and for instrumental non-linearity using calibration gases (natural composition). Further information on instrumentation, including flow diagrams, measurement protocol, calibration of standards and uncertainty estimation can be found in Stanley et al. (2018) and Stavert et al. (2019).

At WAO, 1-minute measurements of CH_4 and N_2O are made using a commercial Fourier Transform Infra-Red Spectrometer (FTIR) instrument (ACOEM SpectronusTM): a detailed description of the FTIR can be found in Hammer et al. (2013). The instrument is routinely calibrated with gases provided by the ICOS Flask and Calibration Laboratory (FCL) and amount fractions are traceable to the WMO calibration scales (Crotwell et al., 2017; Yver-Kwok et al., 2021). While CO_2 amount fraction is measured every second and averaged to 2-minute by a non-dispersive infrared (NDIR) analyser from Siemens Corp. Full details on instrumentation, measurement protocol and calibration strategy can be found in Adcock et al. (2023).

3 Processing of atmospheric radon data: Towards a standard protocol

3.1 Detector control and data collection

Operation of the ANSTO detectors, their data logger and calibration units are controlled by Radon Detector Monitor (RDM) software installed on local site computers. For PC operating systems prior to Windows 10, a Visual Basic GUI version of

350 RDM was distributed. For Windows 10 or later, as well as for Linux systems, a Python-based GUI version of RDM has been available since August 2022 (<https://github.com/anstoradonlab/radon-monitor/releases/>, last access: 24 March 2024). RDM is responsible for the collection, display and storage of all raw detector output (see Figure 3 and elaborated further in Table A2) and based on user-defined parameters, maintains full control of scheduled calibration and background events. However, calibrations and backgrounds can also be remotely reconfigured and initiated if the computer has network connectivity.

355 All measurement and diagnostic quantities associated with the radon detector operation are polled by the internal Campbell Scientific CR800 data logger every 10 seconds, then totalled or averaged every 30 minutes. Totalized counts include LLD, upper limit of discrimination (ULD – electrical noise), and sample flow rate (measured using a domestic gas meter that has a 2.0 L cyclic volume with individual cycles counted optically), while all other parameters are averaged (see Figure 3).

RDM retrieves data from the logger every 30 minutes and saves monthly files in two formats: CSV and SQL database files. 360 The CSV files only contain 30-min records of raw measurement and diagnostic quantities, kept small ($<140 \text{ kB month}^{-1}$) for ease of remote file transfer. The database files contain all 10-second and 30-minute raw and diagnostic quantities, full status and operational information from the calibration system, and a complete log of system and error messages ($<2 \text{ MB month}^{-1}$).




Figure 3. Workflow to calculate the best estimate of radon activity concentration: This flow illustrates the processing steps from measured "raw" detector output through calculated parameters and constants to derive the best estimate of radon activity concentration, described in detail in section 3. The parameters which influence the uncertainty derived from the deconvolution process, are also highlighted (described in subsection 3.7).

3.2 Data quality control, background determination and calibration

The first step of quality control is to check and correct any data timestamping errors. Issues such as power supply disruptions, logger malfunctions, or communication errors can lead to missed, duplicated, or incomplete data records.

LLD counts: The internal and external flow rate, ULD, high voltage, and tank pressure are the critical factors that give the indication whether the LLD count is going to be flagged as valid or invalid. For a given time point, if these parameters varied beyond designated site-specific limits determined to reduce their accuracy, LLD is rejected. LLD was rejected too if it was lower than instrumental background.

The ratio of detector volume (e.g., 1500 L) to sampling flow rate (external flow loop; L min^{-1}) determines the time that sampled air is delayed inside the detector (during which some of the sampled ^{222}Rn will decay). The delay time should be between 15–20 minutes, necessitating a flow rate between 75–100 L min^{-1} .

The flow rate of the internal flow loop should be sufficient to exchange all the air within the detector through the measurement head in less than 3 minutes (the half-life of ^{218}Po). Flow within central pipe of the detector is measured as a velocity (V) with an insertion probe at the centre of the 50 mm ID pipe. Based on the typical velocity profile in a pipe, the actual flow rate is estimated as 80% of the maximum flow rate (Q_{max}). While a flow rate of around 5.5 m s^{-1} is technically sufficient for this purpose, a faster rate is desirable, and values of 6–12 m s^{-1} are typically achievable (based on individual blower performance and flow impedance of the measurement head).

The main detector volume is kept at a slight positive pressure with respect to ambient (described in more detail in 2.2.2) to prevent near-surface air entering the detector should any leaks develop. A large leak would reduce this pressure and a system blockage downstream would increase it. The micro mass flow controller used to estimate this overpressure has a mV output (prone to some calibration drift). An option exists to enter user defined calibration coefficients for this sensor (ideally updated annually) to retrieve output in Pa, but raw output in the range 2200–2400 mV corresponds approximately to an overpressure of 100–120 Pa.

The sensitivity of the photomultiplier tube in the measurement head changes with the supply voltage. The operating high voltage is unique to each detector counting system and is determined when the detector is commissioned (and rechecked if any of the detector electronics are changed). Once set, this value should not be allowed to change by more than $\pm 10 \text{ V}$ without being manually readjusted back to the nominated value.

The counting system of two-filter detectors is sensitive to electrical, electro-magnetic or some radio-frequency noise. Ideally the detectors should be operated on their own power circuit or through an uninterruptible power supply (UPS), and large electrical motors (e.g., pumps, compressors) should not be operated nearby. These forms of noise typically result in raw counts of a higher voltage than counts due to α -decay. A voltage discrimination threshold of 1.0 V is set within the counting electronics to distinguish between raw α -counts from radon progeny (LLD), and noise counts (ULD). Ideally, the ULD counts represent the number of LLD counts that are due to noise. When few noise counts are present (e.g., $\leq 1 \text{ counts min}^{-1}$; site specific), net counts (LLD-ULD) can still be representative raw radon count. Notably, at TAC, ULD counts consistently ranged between 3–7 counts min^{-1} throughout the entire measurement period. It is important to note that this noise originated from the pump of

another instrument. Discarding all measurements made it impractical to implement flagging in this context. Nevertheless, ongoing efforts are being made to develop solutions aimed to mitigate the noise, alongside the ongoing evaluation of uncertainties associated with these noise counts.

400 As an example, Table 1 summarises the designated acceptable limits of diagnostic quantities for the HFD 1500 L radon monitor.

Table 1. Quality check parameters for LLD flagging: Critical factors (internal and external flow rate, ULD, high voltage, differential pressure) with minimum and maximum values – Highlighted through HFD site specific thresholds.

Parameter	Min value	Max value
External flow (L min^{-1})	75	100
Internal flow (m s^{-1})	6	12
Voltage (V)	715	735
Differential pressure (mV)	2000	2600
Upper limit of discrimination ($\text{count (30 min)}^{-1}$)	0	35

The final consideration for flagging the LLD data are background, calibration, and maintenance events, or power failures. The detector is out of operation for the entire 24-hour background check, as well as up to 2 hours after the detector restarts. The detector is also out of operation for the 5-hour source injection period of a calibration, as well as the 6-hour period required to flush the enhanced radon out of the detector. During maintenance periods there are higher risks of ^{220}Rn contamination
 405 (if the detector has been opened) or diagnostic parameters being out of range. After power failures it can take the detector 1–2 hours to return to normal monitoring conditions. All such periods should be flagged out of the final raw dataset prior to further processing.

Instrumental background event: Once background checks had been initiated as outlined in section 2.2.4 and other diagnostic parameters (high voltage and noise; Table 1) were verified to be within acceptable ranges, each background (Figure 4a–c) was processed as follows: the initial 6 hours of the 24-hour period were removed; the last 30-minute sample was excluded if the blowers restarted early (due to the small time differences that can happen between the PC clock and the logger clock if they are not regularly synchronised), and a check was made that the remaining data were approximately constant and free of noise counts. The median of these values was then taken to be the background reading.

415 During the measurement period presented here, an important observation is that each of the three sites depicted in Figure 4a–c experienced an instance where a background event was not recorded. In each case this missing background event was labeled "assigned background", for which the method of determination is explained in the next section 3.3. Typically, instrumental background checks are automated and scheduled quarterly. However, a deviation from this established routine sometimes occurred due to a software crash, leading to a significant gap in the background check process.




Figure 4. Instrumental background events for three sites: a) WAO, b) HFD, and c) TAC, covering the period from the initiation of measurements until August 2021. Assigned background events are highlighted (see section 3.3 for details of assigned values). Corresponding 6-month fitted instrumental background are shown in d) WAO, e) HFD, and f) TAC (see section 3.3 for details of fitting).

420 **Calibration event:** The calibration plan for all radon detectors in this study was for monthly calibrations (scheduled in RDM to occur on the same day of each month) such that the calibration peak (LLD_{peak}) occurred between 13:00–14:00 LST, to coincide with a deep, well-mixed boundary layer. Consequently, any calibration events for which LLD_{peak} did not occur within this time window were rejected. All sites in this study also had regular exposure to “baseline” atmospheric conditions (medium-to-long term oceanic fetch conditions, with low variability in radon concentrations). Consequently, a site-specific
 425 threshold value was set for the ambient radon count representing the upper limit of baseline variability ($50 \text{ counts min}^{-1}$), and any calibration event for which the estimated $LLD_{peak,a}$ exceeded this value was flagged.

Derived monthly calibration factors for all three sites (WAO, HFD, TAC) are presented in Figure 5a–c, covering the period from the initiation of measurements until August 2021. At HFD (Figure 5b), the first 6 months were flagged due to sampling flow problems caused by a partial blockage of the inlet line. Other causes of flagged calibration events in Figure 5a–c, were
 430 attributed to the threshold exceedance of $LLD_{peak,a}$, calibrations occurring at night due to software crashes, and insufficient flushing of the source. For example, the last three calibration events at TAC (Figure 5c, June, July and August 2021) were all too high due to a poorly flushed source. The source flushing time at all sites was originally set to 5 hours (typical for 20 kBq ^{226}Ra sources). However, all sources in this study had activities $>30 \text{ kBq } ^{226}\text{Ra}$ (see Table A1) and it was determined that effective flushing of the source capsules required flushing periods lasting 8–12 hours at 0.15 L min^{-1} . Older-style calibration

435 systems were used in this study (using pumps and needle-valve flow control, not compressed gas and a mass flow controller), so it was important to regularly check and correct the source's flushing.




Figure 5. Monthly calibration coefficients for three sites: a) WAO, b) HFD, and c) TAC, covering the period from the initiation of measurements until August 2021. Flagged calibration events are highlighted (see section 3.2 for exclusion criteria). Corresponding 6-month fitted calibration coefficients are shown in d) WAO, e) HFD, and f) TAC (see section 3.3 for details of fitting).

3.3 Data continuity: Fitting instrument calibration and background

Under normal detector operation, there is no physical basis for short-term deviations from a slow, long-term linear decrease in detector sensitivity (this is controlled by gradual deterioration of consumable materials inside the measurement head). Therefore, such events evident in Fig 5d-f, are more likely a result of uncertainty in the calibration process than real changes in detector performance. This is why the linear model for calibrations described in Chambers et al. (2022), applied retrospectively, is more accurate. When applying fitting algorithms, as described in the following section, to enable continuous near-real-time access to calibrated radon concentrations, it should be understood that additional uncertainty is introduced. To ensure a continuous time series and to avoid unnecessary step changes, the Savitzky-Golay fitting method is used on successive subsets of calibration coefficients and instrumental background counts. This method involves the following steps:

1. **Fitting window size:** Calibration and background values are selected within a specific range. This range as 184-day moving window centred on each of the timestamps.

2. **Fitting:** Within the defined window, a curve is fitted through the selected values using a 1st order polynomial - linear fit, based on the data points available in the defined window.
- 450 3. **Smoothing window size:** The result of the moving fit requires further smoothing. Centre moving average is used as 184-day moving window centred on each of the timestamps.
4. **Smoothing:** The centre moving average is performed on the results of Step 2. This is to smooth out the effect of multiple adjacent data points sharing the same measurements for the fitting, which may result in step changes.
- 455 5. **Handling edge data:** To ensure a smooth transition at the beginning of the dataset, the data points prior to the first calibration/background measurement will be assigned the fitted value from that measurement. Similarly, for the end of the dataset, the fitted value from the last calibration/background measurement will be used to fill in the remaining data points.

For the purpose of reproducibility, the implemented code is provided as supplementary material.

In the rolling fit process, it is crucial to compare the current fitting with the preceding one, particularly in periods of overlap. In this regard, two types of data ranges are recommended: (i) the data range for selecting raw data and performing the fit, and (ii) the data range where the fitted data will actually be utilized. Additionally, the effectiveness of the Savitzky-Golay fitting method can be affected by gaps within the defined window. This issue is evident across three sites, with distinct gaps in background counts observed (see Figure 4). To address this, the concept of "assigned" values is introduced. First, data gaps larger than either the defined half-window size for fitting or a predetermined maximum gap are identified. The number of points to be inserted into these gaps is then determined using the ceiling function:

460

465

$$n = \left\lceil \frac{t_1 - t_0}{\text{gap}_{\max}} \right\rceil \quad (2)$$

where t_1 and t_0 are the time coordinates at either end of the gap. The resulting number of data points to be input are inserted evenly within the gap, with spacing adjusted to the nearest 30 minutes. The gap is then linearly interpolated between the closest available data points to construct this number of new data points, evenly spaced across the gap to the nearest 30 minutes. For HFD, gap_{\max} is set to 93 days

470

The bottom panel of Figures 4d–f and 5d–f display fitted instrumental background (f_{bg}) and the fitted calibration coefficient (f_{cal}) for three sites: WAO, HFD, and TAC. The fitted coefficients reveal a site-dependent annual reduction in detector sensitivity, varying from 3.2 % to 4.7 %. These reduction percentages are calculated based on the fitted calibration coefficients and represent the decline relative to the preceding year. At WAO, situated along the coast with the lowest source strength (see Table A1) and a sampling inlet, the calibration coefficient experienced a 3.2 % p.a. decrease. Similarly, TAC, with the highest sampling inlet, also witnessed sensitivity reductions of 3.3 % p.a., although it recorded the highest background rates among the three sites. The main reason of increased background is the ULD noise but although other factors may also contribute such as ²²⁰Rn contamination at this site and ingrowth of radon from ²²⁶Ra inside the detector. In contrast, the HFD detector

475

exhibited a notably faster sensitivity decrease of 4.7 %, accompanied by the lowest background counts. The acceleration of
 480 reduction in sensitivity and increase in background rate will vary for each instrument, as every batch of materials used for
 making components has distinct levels of trace contamination of ^{226}Ra and different consumable materials within the detector
 head, specifically the $\text{ZnS}(\text{Ag})$ scintillation material. However, it is also worth noting that the fitting procedure can make the
 annual rate of decline appear larger compared to a linear model of calibration sensitivity change. This effect is sometimes more
 pronounced in certain cases, such as in Figure 5d, where edge effects come into play.

485 3.4 Instrument response time correction

The operational principle of two filter detector, briefly discussed in section 2.2.1, inherently causes a delay on reporting the
 true LLD signal. Approximately 40 % of the signal is observed one hour after the radon pulse is delivered (Griffiths et al.,
 2016). This delay necessitates time-response correction, particularly when employing sub-diurnal radon measurements for
 quantitative analysis or comparison with fast-response instruments like GHG ones. Griffiths et al. (2016) explored methods to
 490 correct for the detector's slow response, highlighting the effectiveness of a Bayesian approach using a Markov chain Monte
 Carlo sampler — a methodology employed here for deconvoluting the radon time series. The aim of deconvolution is to
 estimate the true signal within the temporal context while preserving the radon concentration levels. The deconvolution is
 performed on the LLD counts, where all flagged LLD are removed prior to this step. Along with LLD counts, fitted calibration
 coefficient and instrumental background, the deconvolution routine also requires several output parameters: both external and
 495 internal flow rates, the detector's temperature and physical detector's parameters: its size, and the thoron delay volume. The
 fitted instrumental background values are subtracted from the deconvolved LLD counts (LLD_{dec}). Following this subtraction,
 the LLD_{dec} are then processed to calculate the activity concentration (Bq m^{-3}) of ^{222}Rn , the equation is as follows:

$$^{222}\text{Rn} = \frac{(LLD_{dec} - f_{bg})}{1800 \times f_{cal}} \quad (3)$$

For a given timestamp in the time series, the mean of the deconvolution result at that timestamp is reported as the radon
 500 concentration of that particular timestamp.

3.5 Standard reference temperature and pressure correction

The last step of data processing involves normalising the deconvolved concentration of radon to standard reference temperature
 (T_{stp}) and pressure (p_{stp}) conditions (Bq m^{-3} STP). For our case, we adapted the International Standard Atmosphere (288.15
 K and 101325 Pa). This standard was selected mainly due to its representative average, as 15 °C approximates the average
 505 annual ambient temperature of the Earth's surface in temperate regions and makes it easier to be compared across different
 regions and times of the year. This normalisation is achieved through a correction term as follow:

$$^{222}\text{Rn} = \frac{(LLD_{dec} - f_{bg})}{1800 \times f_{cal}} \times \left(\frac{T_{inst}}{p_{inst}} \times \frac{p_{stp}}{T_{stp}} \right) \quad (4)$$

where (T_{inst}) and (p_{inst}) are temperature and pressure inside the detector's main delay volume.

This correction removes sensitivity to measurement height, facilitating comparison with modelled activity concentrations, and ensures that observed trends in radon concentration are solely due to environmental variations in mixing ratio brought about by changing air mass fetch and transport times.

Regarding the harmonisation of radon observations across European and global networks, it should be noted that some atmospheric radon monitors operating within ICOS and other networks (e.g., the HRM, (Levin et al., 2002)), automatically implement an STP correction that assumes different pressure and temperature reference values ($T_{stp}=273.15$ K, $p_{stp}=100000$ Pa). Other monitors (e.g., the ARMON, (Grossi et al., 2012)) do not measure pressure and temperature directly within the instrument delay volume and can therefore only make approximate STP corrections.

3.6 Atmospheric water vapour corrections

Water is a volatile component of the atmosphere. As such, water vapor can vary rapidly in space and time. Through the dilution effect, these changes can influence observed concentrations of other atmospheric constituents. Some radon monitors in European networks (e.g., the ARMON) dry sampled air prior to analysis. Furthermore, modelled radon values are usually reported as dry air mole fractions. For harmonisation and intercomparison purposes, radon monitors should provide the ability to correct for water vapour effects.

ANSTO radon detectors measure the pressure, temperature, and relative humidity (RH) of air in the main delay volume, directly adjacent to the detector measurement head, providing a pathway for water vapour correction if required. However, the process of accurately converting RH into water vapor pressure involves navigating several challenges, including temperature dependencies, measurement accuracy, environmental variability and assumptions in calculation equations. One commonly used method for this conversion is the Clausius-Clapeyron equations, refined with the Magnus approximation, with constants from Alduchov and Eskridge (1996). The equations are based on certain assumptions and empirical data, which might not reflect all environmental conditions, therefore introducing systematic errors. Another critical aspect to consider is that calibration of the radon detector is not based on dry air (the ambient air is used to flush the source), complicating the direct comparisons.

To assess the necessity for correcting water vapor, a simple calculation was carried out to compare the difference between dry (f_{dry}) and wet (f_{wet}) air across a spectrum of UK extreme climate conditions, as indicated in the Table 2. The maximum observed discrepancy of 7.1 % indicated the difference in water vapor concentration between dry and wet air in scenarios of highest temperature and pressure. The discrepancy was minimal (0–2 %) for air temperature spanning 0 to 30 °C. Considering the minimal impact of correcting the water vapor and potential for such correction to introduce noise or errors through another layer of data analysis, especially after the deconvolution process, this correction was omitted. However, detector temperature and RH are reported along with radon concentration so that data users can make this correction themselves, if necessary.

Table 2. Comparison of dry and wet air across UK extreme climate conditions: evaluating the need for water vapor correction.

Scenario	p_{air} (hPa)	T_{air} (°C)	RH (%)	e_s (hPa)	f_{wet}	f_{dry}
1	1053.6	40.3	100	74.93842	0.9558	0.8879
2	1053.6	-27.5	100	0.644756	1.2197	1.2189
3	925.6	40.3	100	74.93842	0.8397	0.7717
4	925.6	-27.5	100	0.644756	1.0715	1.0707
5	1013.2	15.0	100	17.01983	1.0000	0.9832

Note on formulas used: The wet air correction factor (f_{wet}) is calculated with the formula $f_{\text{wet}} = \frac{T_{\text{stp}}}{p_{\text{stp}}} \times \frac{p_{\text{air}}}{T_{\text{air}} + 273.15}$; Similarly, the dry air correction factor (f_{dry}) employs the formula $f_{\text{dry}} = \frac{T_{\text{stp}}}{p_{\text{stp}}} \times \frac{p_{\text{air}} - e_s, RH=100}{T_{\text{air}} + 273.15}$.

3.7 Combined measurement uncertainty

540 The uncertainty associated with the reported radon concentration is derived from the posterior distribution resulting from the deconvolution process. This uncertainty is influenced by:

- **Gross alpha counting:** Governed by a Poisson distribution, this uncertainty reflects the statistical variability inherent in counting process.
- **Flow rate variability:** The external flow rate introduces an uncertainty of 2 %. Variations in the external flow rate, especially rapid changes, can significantly affect the response time of the detector. Griffiths et al. (2016) demonstrated that the deconvolution tends to over-correct the time series if the external flow rate is halved. The internal flow rate contributes a substantial uncertainty of 20 %. Optimizing the internal flow rate is critical for a few reasons: (i) to account for the rapid decay of radon’s first α -emitting progeny (^{218}Po , half-life of 3.1 min), and (ii) to minimize the time for plate-out of unattached radon progeny on the internal surfaces of the detector. To further reduce opportunities for the plate-out of radon progeny inside the detector, a flow homogenization screen is implemented to reduce strong turbulent mixing inside the detector’s main delay volume. This screen ensures a more laminar (plug-like) flow towards the measurement head.
- **Plate-out effect:** An absolute uncertainty of 2 % is given to plate-out effect.
- **Screening efficiency:** A 5 % absolute uncertainty is associated with the screening efficiency on homogenizing airflow and reduce turbulences.
- **Delay time:** The delay time represents the lag in system, with an absolute uncertainty of 1 %, and can arise from various sources such as: extended inlet lines, synchronization of the datalogger etc. While this delay time does not significantly impact the deconvolution routine, it will becomes critical when aligning the detector’s response time with large, brief spike of counts.

560 – **Field calibration coefficient:** The calibration coefficient, with an overall uncertainty of 5 %, incorporates several aspects: the ^{226}Ra source accuracy with an absolute uncertainty of 4 % and additional 1 % uncertainty arises from variation in radon production rate, scaling factor and the decay constant.

In addition to the above-mentioned uncertainties, there are other significant uncertainties that, although not currently addressed, should be considered in future analyses. These include uncertainties related to STP corrections, which typically stem from the accuracy, calibration, and response time of temperature and pressure sensors. A critical area to address is the uncertainty associated with field calibration of 1500 L detectors, that involves interpolating ambient counts (see 2.2.3). Although this problem can be eliminated by employing a portable calibration transfer standard detector (Chambers et al., 2022; Röttger et al., 2023). Another improvement in the uncertainty quantification includes instrumental background and calibration events themselves, alongside the "assigned" values (see 3.3), with the latter one having higher uncertainties.

570 For reporting, half of the difference between the 16th and 84th percentile of the deconvolution result for a particular timestamp is taken as the uncertainty of the radon concentration.

4 Assessing accuracy of the best radon activity concentration estimate

Two approaches are used to evaluate the accuracy of the deconvolved radon concentration. The first approach, under "controlled conditions" employs calibration events to validate both the absolute achieved concentration and the temporal alignment between estimated and measured radon values. The second approach, based on "real-world conditions", directly compares estimated radon concentrations with the GHG amount fractions obtained from fast-response detectors.

4.1 Validating radon activity concentration estimates under controlled conditions

Figure 6a–b depicts calibration events on July 2021 from two locations: HFD and WAO. In each case, radon concentrations ($^{222}\text{Rn}_{\text{ini}}$) were measured following a direct 5-hour injection from a ^{226}Ra source, and then the deconvolution algorithm was applied (^{222}Rn).

Specifically in the case of these events, when the deconvolution algorithm was applied some adjustments were necessary to enhance the algorithm's efficiency. Firstly, because the calibration stream of radon was injected directly into the detector (not at the sampling inlet point), the thoron delay volume value was set to zero. Secondly, since environmental atmospheric radon concentrations do not usually exhibit abrupt changes of the magnitude seen during calibration events, the smoothness constraints of the deconvolution routine were adjusted to accurately track the sudden change in radon concentration as the calibration source is turned on and off.

The purpose of the deconvolution algorithm is to correct the delay between the sampled radon concentration and the detected signal, and here we demonstrate that the implementation of the deconvolution algorithm is successful at the HFD and WAO sites. In the case of a defined calibration injection period from a well-flushed source, the target result is essentially a square wave (bearing in mind that the detector reports concentrations at the end of each measurement period and continues to sample ambient air throughout the injection period). As shown in Figure 6a–b, despite the source injection being initiated at 08:00 LST




Figure 6. Comparison of initial and best radon concentration estimate (with the 16th–84th percentile range shaded) during a calibration event with a constant delivery radon concentration in July 2021 at: a) HFD and b) WAO, alongside a calibration event with non-constant radon delivery in August 2021 at c) HFD. The orange line shows the signal reached only 85 % of its target by 09:00 LST. The shaded area represents the ideal square wave.

at both sites, the signal from both detectors (purple line) had only reached around 85 % of its target value by 09:00 LST. Similarly, after injection stops (13:00 LST at HFD, 14:00 LST at WAO), the signal from each detector takes around 3 hours to return to near ambient. By comparison, the deconvolved signal (yellow line) exhibits a full increase in concentration within the first hour (the temporal resolution of these measurements) and shows an almost complete return to ambient concentrations in the hour after injection stops. The observed behaviour of the response time corrected data demonstrates the effectiveness of the deconvolution process in recreating sudden, unrealistically large, changes in radon concentration, lending credence to the claimed accuracy, precision and reliability under real-world scenarios.

As evident in Figure 6a–b, when the deconvolved radon signal from a calibration injection depicts a near-ideal square wave, it usually takes the uncorrected detector output 3 to 5 hours to reach a similar activity concentration (based on overlapping uncertainty bounds). Often, something that is more clearly evident in the deconvolved output for calibration injection events are times when the source capsule had not been adequately flushed prior to the start of an injection (see Figure 6c). In these cases, a clear “overshoot” of radon concentration is observed, followed by a gradual return to the target concentration over the 5-hour injection period as the excess radon is flushed from the detector’s main delay volume. These tests of the deconvolution routine on extreme changes under controlled conditions provide confidence in the fidelity of the technique under real-world conditions.

4.2 Validation of best estimated radon activity concentration under real-world conditions

Changes in air mass fetch, transitioning from terrestrial to oceanic or vice versa, lead to significant variations in atmospheric trace gas constituents. When associated with strong frontal systems, such changes can occur over short timescales – comparable to the 3–5 hours it takes a two-filter radon detector to fully respond to a sustained calibration injection.

In Figure 7, we illustrate the response of CH₄ as measured by a fast-response analyzer (0.4 Hz) to a rapid change in air mass fetch during the winter period (22–23 February 2021) at HFD and WAO. Additionally, the Figure 7 presents the corresponding radon measurements, both with and without response time correction via deconvolution.

Initially, on February 22, a period of pollution is evident, characterized by elevated radon concentrations and CH₄ amount fractions, attributed to continental influences. However, a rapid transition to baseline conditions for both gases occurs as air masses shift towards cleaner oceanic origins on February 23. This transition is corroborated by air history maps generated using the Met Office NAME Lagrangian atmospheric dispersion model for each site (not shown here).

Analyzing the reference CH₄ time series reveals the elimination of time lag between CH₄ amount fraction and deconvolved radon compared to the initial measurements. Moreover, at both sites, the duration of CH₄ transition from polluted peak to baseline conditions aligns with deconvolved radon measurements.

Accurately representing radon concentrations holds significant importance, particularly when radon is used as a quantitative tracer such as improving and validating ATMs as well as estimating local-to-regional GHG fluxes via RTM (Biraud et al., 2000; Levin et al., 2021).




Figure 7. Response of CH₄ and radon (initial and best estimate) to rapid air mass changes in winter: a) HFD and b) WAO.

Trace gases can mix through the depth of the planetary boundary layer (PBL) on timescales of around 1-hour (Stull, 1988). Consequently, before attempting to employ radon to improve understanding of the dilution of atmospheric constituents with surface sources it is crucial that instrument response time is accounted for (see Figure 10 in Griffiths et al. (2016)). Here we further demonstrate the effectiveness of the deconvolution technique under real-world conditions by analysing diurnal composites of radon, CH₄, CO₂, and N₂O. The diurnal cycle of trace gases with surface sources is characterised by a morning maximum, when the mixing depth is shallowest, and an afternoon minimum, when convective mixing is deepest. After sunrise, when the nocturnal inversion breaks down and the daytime inversion begins to grow, concentrations reduce rapidly from their morning maximum to their afternoon minimum values. In the absence of short-term sinks (e.g., photosynthesis) or temporal changes in source function, all gases should be impacted equally by this dilution.

Focusing primarily on the warmer season - summer - is crucial for our analysis because of gases pronounced diurnal variation in PBL height. This variation offers an ideal testing ground to evaluate the effectiveness of the radon deconvolution tool.

635 Hourly median summer diurnal composites of best estimated radon (deconvolved and STP corrected) and GHGs at TAC, HFD, and WAO are presented in Figure 8. At each of these sites, radon and the GHGs were sampled from the same (uppermost) inlet height. However, there was an exception at TAC, where radon was sampled at 175 m a.g.l., while GHGs were sampled slightly higher at 185 m a.g.l.

640 During summer nights, the sampling inlets at TAC (175/185 m a.g.l.) and HFD (100 m a.g.l.) are typically positioned above the inversion layer. However, the results presented here are based on seasonal median values, which exclude the most extreme and strongly stable nighttime conditions. As a result, for the plots shown (see Figure 8a–b), the inlet heights are effectively situated just at the top of the inversion layer.

The rate of increase in nocturnal median levels of trace gases at these sites is small, and a noticeable increase begins around 05:00 LST (coinciding with sunrise) and peaks at 08:00 LST. Figure 8a (TAC and HFD) indicate synchronous 08:00 LST peaks in radon and CH₄ at both towers. This behaviour is consistent with the destruction of the inversion layer at some time after 05:00 LST, allowing these gases that had accumulated near the surface to mix upwards slowly, past the sampling inlets (typically at or before 08:00 LST). By contrast, WAO measurements are consistently made well within the nocturnal inversion (10 m a.g.l.), and a distinct pattern of decreasing CH₄ and radon levels is observed after sunrise (WAO: Figure 8a).

650 The observation of simultaneous peaks in CH₄ and deconvolved radon across all three sites with contrasting sampling heights is a clear validation of the deconvolution technique, highlighting its ability to accurately represent the significant impact of diurnal atmospheric processes on radon concentrations.

The difference in radon concentration peaks compared to CO₂ amount fractions at all sites, however, highlights the unique response of these gases to both physical and biological processes (Figure 8b–c). The morning peak of CO₂ is observed to occur three hours earlier than the radon peak at both TAC and HFD sites. This difference can be attributed to the onset of photosynthetic activity. CO₂, being continuously released by soil respiration, is more quickly affected by surface air movements and sunlight-triggered processes like photosynthesis. As a result, CO₂ is rapidly absorbed by vegetation, resulting in a notable reduction in atmospheric CO₂ levels. In contrast, radon, CH₄, N₂O are less affected by these immediate factors and thus takes longer to mix upward from its accumulation near the surface at a slower rate.

660 It is commonly assumed that mixing within the nocturnal boundary layer is uniform; however, this is not the case. A concentration gradient exists from just below the inversion layer to the surface. This gradient is illustrated in Figure 9 which shows CO₂ measurements at both the lowest sampling point at HFD (50 m a.g.l.), and the highest sampling point (100 m a.g.l.). The breakdown of the inversion layer around 05:00 LST facilitates vertical mixing of accumulated CO₂ at 50 m a.g.l., a process clearly depicted in the Figure 9 which also affects the readings from the 100 m inlet.

665 At TAC, the morning peak of N₂O is observed at 06:00 LST, two hours earlier than the radon peak at 08:00 LST (see Figure 8c). This earlier peak can be attributed to soil microbial activity, particularly during nitrification and denitrification processes that are triggered by rising temperatures and increasing sunlight. In contrast, at the HFD and WAO sites, where the inlet is positioned 85 m and 175 m lower than at TAC, N₂O and radon peaks occur simultaneously. This difference in inlet height significantly affects the mixing dynamics at these locations.




Figure 8. Summer diurnal composites of best estimated radon activity concentration and GHG amount fractions at TAC, HFD and WAO shown in panels: a) radon and CH₄, b) radon and CO₂, and c) radon and N₂O. Composites are based on hourly median values spanning June to August. Shaded areas indicate the 25th to 75th percentile to visualize variability of gases.




Figure 9. Diurnal composites of best estimated radon activity concentration and CO₂ amount fractions measured at 50 and 100 m a.g.l. at HFD during summer. Composites are based on hourly median values. Shaded areas indicate the 25th to 75th percentile to visualize variability of gases.

At the WAO coastal site, the difference in median peak times between radon and CO₂ is likely driven by their distinct source/sink functions (Figure 8b), as well as land/sea breezes. Radon exhibits a relatively constant source/sink function compared to CO₂. Consequently, the radon concentration observed at 10 m a.g.l. is primarily influenced by atmospheric dynamics, particularly the formation and breakdown of the nocturnal inversion, with the peak typically occurring just before the inversion breaks down. Conversely, CO₂ experiences influences from both dynamics and a temporally variable source/sink function. At WAO, CO₂ peaks earlier than radon because photosynthesis begins immediately when the sun rises, drawing CO₂ out of the nocturnal inversion before convective mixing begins, which typically takes an hour or two to initiate due to the warming up process. However, the shaded areas representing the 25th to 75th percentile range for CO₂ variability suggest that this peak frequently coincides with the radon peak.

5 Recommendations

5.1 Instrument maintenance

As detailed in Section 2.2.2 some periodic maintenance of ANSTO two-filter radon detectors is required. Note, some of this information is also included in the commissioning report of ANSTO instrument.

Weekly:

- Visually check that data are updating half-hourly to ensure continuous logging. This can be done remotely.

Monthly:

- Synchronise the data logger and PC clocks.
- Verify that scheduled events such as calibrations and backgrounds have occurred. This can also be done remotely.

Quarterly:

- If not using a compressed air calibration system, inspect and shake the calibration unit's desiccant tube. Confirm that the injection flow rate is within the range of 0.10–0.15 L min⁻¹.

Yearly:

- Check the detector and inlet system for leaks, with half-yearly checks recommended for detectors located outside.
- Inspect the plumbing of the calibration system.
- Check or replace the coarse aerosol filter on the inlet line.

2-yearly:

- If using a compressed air calibration system, replace the gas bottle.

5-yearly:

- Refresh the materials inside the detector head (stainless steel mesh filter and ZnS(Ag) sheet). If components of the aluminium frame of the head have started to corrode, the head casing should also be replaced. ANSTO can provide this service or instructions for replacement (contact: radon@ansto.gov.au).

700 10-yearly:

- Replace all moving and electrical parts, including power supplies. ANSTO can assist with this service or provide instructions.

5.2 Instrument calibration and background

By default, the user specifies a schedule for instrument calibration and background checks. From a meteorological perspective, the calibration events will occur randomly. Each year, some calibrations will occur under conditions that closely satisfy the assumptions of the calibration process. Only these events should be retained.

Alternatively, background events can still be scheduled on an automatic, regular basis, but the calibrations can be remotely triggered every 1–2 months, according to forecast meteorological conditions better meeting the assumptions of the calibration process. Automatic background checks will not account for any self-generation of radon inside the detector by trace amounts of ^{226}Ra . To ensure continuity in case of software crashes or other issues, it is recommended to schedule background events to run automatically on a 2-monthly basis.

To achieve the lowest possible calibration uncertainty, a mobile calibration transfer standard device can be moved to the site once per year to run in parallel with the 1500 L radon detector for around two-weeks, to transfer a traceable calibration and instrumental background. The transferred background will account for self-generation of radon inside the detector by trace amounts of ^{226}Ra . Information about the availability of these transfer standard instruments can be obtained by contacting radon@ansto.gov.au.

5.3 Software

For Windows 10 operating systems and higher the Visual Basic version of the RDM control software has been increasingly unstable. For these systems, or to operate the software from a Unix/Linux platform, we recommend moving to the Python based version of RDM (<https://github.com/anstoradonlab/radon-monitor/releases/>). Additional features of the Python based control software include access to raw 10-second output of all detector parameters (as well as the 30-minute averages), access to a log of all system messages and error messages, access to a comprehensive log of all operational parameters of the calibration unit (if using a compressed air Burkert calibration system).

The graphical radon data processing software to perform all procedures described in Section 3.2 on the 30-minute instrument output apart from the deconvolution process was developed (available upon request). The software was currently developed and tested under Windows 10 or higher platforms.

5.4 Quality health workflow

A three stage data quality control regime is recommended:

730 **Monthly:** new data files should be checked for timestamping errors (missing, partial or duplicate records) and data flagged if key diagnostic parameters are out of range (Table 1).

Quarterly: Monthly calibrations and quarterly background check should be processed and reviewed, and if feasible fitting should be conducted.

735 **6-month (final data product):** 6-month fitted calibration coefficient and instrumental background are reviewed, along the executing of deconvolution code and STP correction to derive the best estimate of radon concentration together with associated uncertainties. In this stage, it is recommended that a simultaneous review of data from multiple sites to be conducted. This approach enables for comprehensive analysis and comparison, facilitating the identification of any anomalies or inconsistencies that may require further investigation.

5.5 Data levels for dissemination

740 Data obtained from ANSTO two-filter radon detectors can be disseminated across various temporal scales, including near real-time (level 1) and 6-month (level 1) or long-term intervals. Each temporal scale is associated with different relative uncertainties, which should be clearly documented in the metadata. To process raw counts into radon concentrations, aside from response time correction, it is necessary to remove background counts and apply calibration. Both the background count and the calibration coefficient can be modelled, with the accuracy and complexity of these models varying based on the available data.

745 When a detector is first commissioned, initial estimates of calibration coefficient and instrumental background count are determined. These values serve as constants for deriving near real-time radon concentrations during the first 6 months of operation. Subsequently, the calibration and background history is reviewed, and fitted values for the next 6 months are derived. To update the calibration coefficient and instrumental background for the subsequent month (e.g., month 7), the last value from the fitting is utilized. It is noteworthy that the commissioning background check may involve thoron contamination and may
750 need to be disregarded. For near real-time measurements, deconvolution can be run routinely with the code taking about one minute to process one day's worth of data. Deconvolution is then re-run in postprocessing after the finalisation of the calibration coefficients and background count rate time series."

755 The availability of level 1 data on 6-monthly basis is highly desirable for the modelers, particularly for evaluating operational data model integration, in this case employing radon to assess the accuracy of ATMs. Implementing a routine and operational radon approach facilitates the ongoing assessment of the accuracy of these transport models, thereby enhancing the accuracy of GHG emission estimates.

After one full year of measurements are available, the consistency and seasonality of calibration factors can be assessed, and a representative average value calculated for the year. The available background checks can be assessed for consistency and a linear model applied. This year of data should be processed with this information and archived, and this calibration factor and

760 background model should then be used to generate the “near real time” data for the subsequent year of measurements. This process is complete after 5 years when the detector’s measurement head is replaced, and the process starts again.

Data from the UK radon network are stored at the Centre for Environmental Data Analysis (CEDA), while data from the ICOS network may be accessible through the ICOS portal; additionally, GAW/WMO radon data could be archived at the World Data Centre for Greenhouse Gases (WDCGG).

765 **6 Conclusions**

In this study, we have developed a comprehensive protocol to enhance the reliability of reported radon activity concentrations for real-time applications, enabling their direct comparison alongside GHG measurements within a monitoring network of three independently managed observatories in the UK.

Our protocol emphasizes the importance of achieving radon measurements with accuracy and resolution comparable to 770 GHGs, necessitating specific procedures for quality control, calibration, deconvolution, and uncertainty assignment. Validation of this protocol through meticulous analysis of calibration events and comparison with GHG measurements establishes a foundation for standardizing protocols across networks (ICOS and GAW) using two-filter instruments to measure radon.

The critical role of deconvolution in preserving the true signal of radon, particularly for quantitative tracer applications in atmospheric studies, is underscored. Our analysis demonstrates the adaptability of the deconvolution technique across seasonal 775 variations and distinct atmospheric dynamics, ensuring accuracy in tracking GHG trends across all sites and validating ATM outputs. Synchronization of radon peaks with GHGs, especially during summer diurnal variations, further validates the effectiveness of our deconvolution method in real-world conditions, highlighting radon’s importance as a tracer in understanding atmospheric mixing.

This study offers a robust protocol for radon measurement within GHG monitoring networks and underscores the invaluable 780 role of radon as an independent metric in ATMs. By ensuring the accuracy and comparability of radon measurements, may contribute to refining GHG emissions estimates and improving understanding of atmospheric processes, and could be a significant contribution to climate change mitigation and the achievement of the Paris Agreement.

Code and data availability. The graphical radon data processing software described in Section 5.3 is available upon request. The runtime script for the python-based research package used for this study is available upon request. Software implementing the deconvolution algorithm (Section 3.4) can be found at <https://github.com/anstoradonlab/rdfix>. The fitting algorithm described in Section 3.3 is available as supplementary material. Radon and GHG data from the Heathfield, Tacolneston and Weybourne are available from the Centre for Environmental Data Analysis (CEDA) data at <https://dx.doi.org/10.5285/bd7164851bcc491b912f9d650fcf7981>.

Appendix A: Appendix A

Table A1. Site-specific radon source strength (Pylon 2000A ^{226}Ra).

Site	Source strength (kBq)
TAC	49.138
RGL	49.197
HFD	49.311
WAO	41.822

Table A2. Summary of dual-flow-loop two filter radon detector outputs, description and units

Detector output (parameters)	Description	Unit
Date	timestamp represents the end of measurement interval	dd mm yy hh:mm:ss
external_flow	moves sampled air from intake point, inlet pipe, thoron delay, primary filter, into the detector delay volume and out of exhaust valve	L min^{-1}
internal_flow	Circulates sampled air from the enclosure containing both blowers, through the flow homogenising denim screen, down the length of the delay volume, through the detector head and secondary filter, along the central pipe, and back to the blower enclosure	m s^{-1}
LLD	lower level of discrimination	$\text{count (30 min)}^{-1}$
ULD	upper level of discrimination	$\text{count (30 min)}^{-1}$
differential_press	differential pressure between the detector tank and ambient air	mV
logger_temp	temperature inside the logger	$^{\circ}\text{C}$
detector_temp	temperature inside the detector tank	$^{\circ}\text{C}$
detector_RH	relative humidity inside the detector tank	%
detector_press	absolute pressure inside the detector tank	hPa
voltage	photomultiplier high voltage	V
bg_lld	instrumental background	$\text{count (30 min)}^{-1}$
cal_coeff	monthly calibration coefficient	$\text{count s}^{-1} (\text{Bq m}^{-3})^{-1}$
bg_lld_inter	6-month interpolated background	$\text{count (30 min)}^{-1}$
cal_coeff_inter	6-month interpolated calibration	$\text{count s}^{-1} (\text{Bq m}^{-3})^{-1}$
radon_initial	calibrated radon activity concentration based on LLD, calibration and background interpolated value	Bq m^{-3}
radon	deconvolved calibrated radon activity concentration corrected for standard temperature and pressure (best estimate of radon activity concentration)	Bq m^{-3} (STP)
radon_uncertainty	combined uncertainties	Bq m^{-3} (STP)

790 *Author contributions.* DK led the research design, performed all data visualizations, and developed the concepts and results. The develop-
ment of a standardized protocol was a joint effort by DK, EC, SC, AG, TA, GF, and AW. Radon measurements and calibration at HFD were
conducted by DK, at WAO by GF, and at TAC by AW. EC developed the software for radon quality control, performing data checks and
deconvolution run across all sites, with support from DK, AW, GF, and AG. GHG measurement responsibilities were divided as follows: TA,
CR, ES and DK for HFD, GF, LF, PP, KA for WAO, and SD, JP, DY, KS and AW for TAC. DK wrote the complete original draft of the paper,
with SC, AG, PP, AW, EC, JP, CR and TA contributing to the editing and review process.

795 *Competing interests.* At least one of the (co-)authors is a member of the editorial board of Atmospheric Measurement Techniques.

800 *Acknowledgements.* Funding for this work is primarily through the NPL Directors' Fund, National Measurement System Funding and
NERC - Building a Green Future: GEMMA Greenhouse Gas Emissions Measurement and Modelling Advancement project. The ANSTO
radon detectors for this work and the Picarro G5310 at HFD were purchased from the UKRI NERC grant 'Advanced UK Observing Network
For Air Quality, Public Health and Greenhouse Gas Research' in 2018, awarded to University of Edinburgh, University of Bristol and
University of East Anglia. The authors thank Andrew Manning and Alex Etchells (both University of East Anglia) for maintained with
support CO₂ measurement system at WAO and Mr Ot Sisoutham of ANSTO for construction and initial testing of all two-filter radon
detectors used in this study.

References

- Adcock, K. E., Pickers, P. A., Manning, A. C., Forster, G. L., Fleming, L. S., Barningham, T., Wilson, P. A., Kozlova, E. A., Hewitt, M., Etchells, A. J., and Macdonald, A. J.: 12 years of continuous atmospheric O₂, CO₂ and APO data from Weybourne Atmospheric Observatory in the United Kingdom, *ESSD*, 15, 5183–5206, <https://doi.org/10.5194/essd-15-5183-2023>, 2023.
- Arnold, T., Manning, A. J., Kim, J., Li, S., Webster, H., Thomson, D., Mühle, J., Weiss, R. F., Park, S., and O’Doherty, S.: Inverse modelling of CF₄ and NF₃ emissions in East Asia, *Atmos. Chem. Phys.*, 18, 13 305–13 320, <https://doi.org/10.5194/acp-18-13305-2018>, 2018.
- Baker, D. F., Law, R. M., Gurney, K. R., Rayner, P., Peylin, P., Denning, A. S., Bousquet, P., Bruhwiler, L., Chen, Y.-H., Ciais, P., Fung, I. Y., Heimann, M., John, J., Maki, T., Maksyutov, S., Masarie, K., Prather, M., Pak, B., Taguchi, S., and Zhu, Z.: TransCom 3 inversion intercomparison: Impact of transport model errors on the interannual variability of regional CO₂ fluxes, 1988–2003, *Global Biogeochem. Cycles*, 20, <https://doi.org/10.1029/2004GB002439>, 2006.
- Bergamaschi, P., Corazza, M., Karstens, U., Athanassiadou, M., Thompson, R. L., Pison, I., Manning, A. J., Bousquet, P., Segers, A., Vermeulen, A. T., Janssens-Maenhout, G., Schmidt, M., Ramonet, M., Meinhardt, F., Aalto, T., Haszpra, L., Moncrieff, J., Popa, M. E., Lowry, D., Steinbacher, M., Jordan, A., O’Doherty, S., Piacentino, S., and Dlugokencky, E.: Top-down estimates of European CH₄ and N₂O emissions based on four different inverse models, *Atmos. Chem. Phys.*, 15, 715–736, <https://doi.org/10.5194/acp-15-715-2015>, 2015.
- Bergamaschi, P., Karstens, U., Manning, A. J., Saunio, M., Tsuruta, A., Berchet, A., Vermeulen, A. T., Arnold, T., Janssens-Maenhout, G., Hammer, S., Levin, I., Schmidt, M., Ramonet, M., Lopez, M., Lavric, J., Aalto, T., Chen, H., Feist, D. G., Gerbig, C., Haszpra, L., Hermansen, O., Manca, G., Moncrieff, J., Meinhardt, F., Necki, J., Galkowski, M., O’Doherty, S., Paramonova, N., Scheeren, H. A., Steinbacher, M., and Dlugokencky, E.: Inverse modelling of European CH₄ emissions during 2006–2012 using different inverse models and reassessed atmospheric observations, *Atmos. Chem. Phys.*, 18, 901–920, <https://doi.org/10.5194/acp-18-901-2018>, 2018.
- Biraud, S., Ciais, P., Ramonet, M., Simmonds, P., Kazan, V., Monfray, P., O’Doherty, S., Spain, T. G., and Jennings, S. G.: European greenhouse gas emissions estimated from continuous atmospheric measurements and radon 222 at Mace Head, Ireland, *Geophys. Res. Atmos.*, 105, 1351–1366, <https://doi.org/10.1029/1999JD900821>, 2000.
- Brown, P., Cardenas, L., Del Vento, S., Karagianni, E., MacCarthy, J., Mullen, P., Passant, N., Richmond, B., Thistlethwaite, G., Thomson, A., Wakeling, D., and Willis, D.: UK greenhouse gas inventory, 1990 to 2021: annual report for submission under the Framework Convention on Climate Change, https://naei.beis.gov.uk/reports/reports?report_id=1108, ISBN: 9780993397592 Num Pages: 601 Place: Didcot Publisher: Ricardo Energy & Environment, 2023.
- Chambers, S., Williams, A. G., Zaborowski, W., Griffiths, A., and Crawford, J.: Separating remote fetch and local mixing influences on vertical radon measurements in the lower atmosphere, *Tellus B: Chemical and Physical Meteorology*, 63, <https://b.tellusjournals.se/articles/10.1111/j.1600-0889.2011.00565.x>, 2011.
- Chambers, S. D., Williams, A. G., Crawford, J., and Griffiths, A. D.: On the use of radon for quantifying the effects of atmospheric stability on urban emissions, *Atmospheric Chemistry and Physics*, 15, 1175–1190, <https://doi.org/10.5194/acp-15-1175-2015>, publisher: Copernicus GmbH, 2015.
- Chambers, S. D., Williams, A. G., Conen, F., Griffiths, A. D., Reimann, S., Steinbacher, M., Krummel, P. B., Steele, L. P., Schoot, M. V. v. d., Galbally, I. E., Molloy, S. B., and Barnes, J. E.: Towards a Universal “Baseline” Characterisation of Air Masses for High- and Low-Altitude Observing Stations Using Radon-222, *Aerosol Air Qual. Res.*, 16, 885–899, <https://doi.org/10.4209/aaqr.2015.06.0391>, publisher: Taiwan Association for Aerosol Research, 2016.

- Chambers, S. D., Guérette, E.-A., Monk, K., Griffiths, A. D., Zhang, Y., Duc, H., Cope, M., Emmerson, K. M., Chang, L. T., Silver, J. D.,
840 Utembe, S., Crawford, J., Williams, A. G., and Keywood, M.: Skill-Testing Chemical Transport Models across Contrasting Atmospheric
Mixing States Using Radon-222, *Atmosphere*, 10, 25, <https://doi.org/10.3390/atmos10010025>, 2019a.
- Chambers, S. D., Podstawczyńska, A., Pawlak, W., Fortuniak, K., Williams, A. G., and Griffiths, A. D.: Characterizing the State of the Urban
Surface Layer Using Radon-222, *Journal of Geophysical Research: Atmospheres*, 124, 770–788, <https://doi.org/10.1029/2018JD029507>,
_eprint: <https://onlinelibrary.wiley.com/doi/pdf/10.1029/2018JD029507>, 2019b.
- 845 Chambers, S. D., Griffiths, A. D., Williams, A. G., Sisoutham, O., Morosh, V., Röttger, S., Mertes, F., and Röttger, A.: Portable two-filter
dual-flow-loop ²²²Rn detector: stand-alone monitor and calibration transfer device, vol. 57, pp. 63–80, <https://doi.org/10.5194/adgeo-57-63-2022>, iSSN: 1680-7340, 2022.
- Chevillard, A., Ciais, P., Karstens, U., Heimann, M., Schmidt, M., Levin, I., Jacob, D., Podzun, R., Kazan, V., Sartorius, H., and Weingartner,
E.: Transport of ²²²Rn using the regional model REMO: a detailed comparison with measurements over Europe, *Tellus B: Chem. Phys.*
850 *Meteorol.*, 54, 850–871, <https://doi.org/10.3402/tellusb.v54i5.16735>, 2002.
- Ciais, P., Dolman, A. J., Bombelli, A., Duren, R., Peregón, A., Rayner, P. J., Miller, C., Gobron, N., Kinderman, G., Marland, G., Gruber, N.,
Chevallier, F., Andres, R. J., Balsamo, G., Bopp, L., Bréon, F.-M., Broquet, G., Dargaville, R., Battin, T. J., Borges, A., Bovensmann, H.,
Buchwitz, M., Butler, J., Canadell, J. G., Cook, R. B., DeFries, R., Engelen, R., Gurney, K. R., Heinze, C., Heimann, M., Held, A., Henry,
M., Law, B., Luysaert, S., Miller, J., Moriyama, T., Moulin, C., Myneni, R. B., Nussli, C., Obersteiner, M., Ojima, D., Pan, Y., Paris, J.-D.,
855 Piao, S. L., Poulter, B., Plummer, S., Quegan, S., Raymond, P., Reichstein, M., Rivier, L., Sabine, C., Schimel, D., Tarasova, O., Valentini,
R., Wang, R., van der Werf, G., Wickland, D., Williams, M., and Zehner, C.: Current systematic carbon-cycle observations and the need
for implementing a policy-relevant carbon observing system, *Biogeosciences*, 11, 3547–3602, <https://doi.org/10.5194/bg-11-3547-2014>,
2014.
- Crotwell, A., Steinbacher, M., Organization (WMO), W. M., and 19th WMO/IAEA Meeting on Car-
860 bon Dioxide: 19th WMO/IAEA Meeting on Carbon Dioxide, Other Greenhouse Gases and Re-
lated Measurement Techniques (GGMT-2017), Tech. rep., WMO, [https://library.wmo.int/records/item/37000-19th-wmo-iaea-meeting-on-carbon-dioxide-other-greenhouse-gases-and-related-measurement-techniques-ggmt-2017#](https://library.wmo.int/records/item/37000-19th-wmo-iaea-meeting-on-carbon-dioxide-other-greenhouse-gases-and-related-measurement-techniques-ggmt-2017#.Xmdl6Oko9rk)
.Xmdl6Oko9rk, 2017.
- Dentener, F., Feichter, J., and Jeuken, A.: Simulation of the transport of ²²²Rn using on-line and off-line global models at
865 different horizontal resolutions: a detailed comparison with measurements, *Tellus B: Chem. Phys. Meteorol.*, 51, 573–602,
<https://doi.org/10.3402/tellusb.v51i3.16440>, 1999.
- Eve, A.: LI. On the amount of radium emanation in the atmosphere near the earth's surface, *London Edinburgh Philos. Mag. J. Sci.*, 16,
622–632, <https://doi.org/10.1080/14786441008636540>, 1908.
- Fleming, Z. L., Monks, P. S., and Manning, A. J.: Review: Untangling the influence of air-mass history in interpreting observed atmospheric
870 composition, *Atmos. Res.*, 104–105, 1–39, <https://doi.org/10.1016/j.atmosres.2011.09.009>, 2012.
- Forster, G. L., Sturges, W. T., Fleming, Z. L., Bandy, B. J., and Emeis, S.: A year of H₂ measurements at Weybourne Atmospheric Observa-
tory, UK, *Tellus B: Chem. Phys. Meteorol.*, 64, 17 771, <https://doi.org/10.3402/tellusb.v64i0.17771>, 2012.
- Galmarini, S.: One year of ²²²Rn concentration in the atmospheric surface layer, *Atmos. Chem. Phys.*, 6, 2865–2886,
<https://doi.org/10.5194/acp-6-2865-2006>, 2006.

- 875 Ganesan, A. L., Manning, A. J., Grant, A., Young, D., Oram, D. E., Sturges, W. T., Moncrieff, J. B., and O'Doherty, S.: Quantifying methane and nitrous oxide emissions from the UK and Ireland using a national-scale monitoring network, *Atmos. Chem. Phys.*, 15, 6393–6406, <https://doi.org/10.5194/acp-15-6393-2015>, 2015.
- Geels, C., Gloor, M., Ciais, P., Bousquet, P., Peylin, P., Vermeulen, A. T., Dargaville, R., Aalto, T., Brandt, J., Christensen, J. H., Frohn, L. M., Haszpra, L., Karstens, U., Rödenbeck, C., Ramonet, M., Carboni, G., and Santaguida, R.: Comparing atmospheric transport models
880 for future regional inversions over Europe – Part 1: mapping the atmospheric CO₂ signals, *Atmospheric Chemistry and Physics*, 7, 3461–3479, <https://doi.org/10.5194/acp-7-3461-2007>, publisher: Copernicus GmbH, 2007.
- Gerbig, C., Körner, S., and Lin, J. C.: Vertical mixing in atmospheric tracer transport models: error characterization and propagation, *Atmospheric Chemistry and Physics*, 8, 591–602, <https://doi.org/10.5194/acp-8-591-2008>, publisher: Copernicus GmbH, 2008.
- Griffiths, A. D., Chambers, S. D., Williams, A. G., and Werczynski, S.: Increasing the accuracy and temporal resolution of two-filter
885 radon-222 measurements by correcting for the instrument response, *Atmos. Meas. Tech.*, 9, 2689–2707, <https://doi.org/10.5194/amt-9-2689-2016>, 2016.
- Grossi, C., Arnold, D., Adame, J. A., López-Coto, I., Bolívar, J. P., de la Morena, B. A., and Vargas, A.: Atmospheric ²²²Rn concentration and source term at El Arenosillo 100 m meteorological tower in southwest Spain, *Radiat. Meas.*, 47, 149–162, <https://doi.org/10.1016/j.radmeas.2011.11.006>, 2012.
- 890 Grossi, C., Vogel, F. R., Curcoll, R., Àgueda, A., Vargas, A., Rodó, X., and Morguí, J.-A.: Study of the daily and seasonal atmospheric CH₄ mixing ratio variability in a rural Spanish region using ²²²Rn tracer, *Atmos. Chem. Phys.*, 18, 5847–5860, <https://doi.org/10.5194/acp-18-5847-2018>, 2018.
- Grossi, C., Chambers, S. D., Llido, O., Vogel, F. R., Kazan, V., Capuana, A., Werczynski, S., Curcoll, R., Delmotte, M., Vargas, A., Morguí, J.-A., Levin, I., and Ramonet, M.: Intercomparison study of atmospheric ²²²Rn and ²²²Rn progeny monitors, *Atmos. Meas. Tech.*, 13,
895 2241–2255, <https://doi.org/10.5194/amt-13-2241-2020>, 2020.
- Gurney, K. R., Huang, J., and Coltin, K.: Bias present in US federal agency power plant CO₂ emissions data and implications for the US clean power plan, *Environ. Res. Lett.*, 11, 064005, <https://doi.org/10.1088/1748-9326/11/6/064005>, 2016.
- Hammer, S., Griffith, D. W. T., Konrad, G., Vardag, S., Caldow, C., and Levin, I.: Assessment of a multi-species in situ FTIR for precise atmospheric greenhouse gas observations, *Atmos. Meas. Tech.*, 6, 1153–1170, <https://doi.org/10.5194/amt-6-1153-2013>, 2013.
- 900 Hirao, S., Yamazawa, H., Moriizumi, J., Yoshioka, K., and Iida, T.: Development and verification of long-range atmospheric Radon-222 transport model, *J. Nucl. Sci. Technol.*, 45, 166–172, <https://doi.org/10.1080/00223131.2008.10876001>, 2008.
- Hirsch, A. I.: On using radon-222 and CO₂ to calculate regional-scale CO₂ fluxes, *Atmospheric Chemistry and Physics*, 7, 3737–3747, <https://doi.org/10.5194/acp-7-3737-2007>, publisher: Copernicus GmbH, 2007.
- Israël, H., Horbert, M., and Israël, G. W.: Results of continuous measurements of radon and its decay products in the lower atmosphere,
905 *Tellus*, 18, 639–642, <https://doi.org/10.3402/tellusa.v18i2-3.9204>, 1966.
- Jacob, D. J., Prather, M. J., Rasch, P. J., Shia, R.-L., Balkanski, Y. J., Beagley, S. R., Bergmann, D. J., Blackshear, W. T., Brown, M., Chiba, M., Chipperfield, M. P., de Grandpré, J., Dignon, J. E., Feichter, J., Genthon, C., Grose, W. L., Kasibhatla, P. S., Köhler, I., Kritz, M. A., Law, K., Penner, J. E., Ramonet, M., Reeves, C. E., Rotman, D. A., Stockwell, D. Z., Van Velthoven, P. F. J., Verver, G., Wild, O., Yang, H., and Zimmermann, P.: Evaluation and intercomparison of global atmospheric transport models using ²²²Rn and other short-lived tracers,
910 *Geophys. Res. Atmos.*, 102, 5953–5970, <https://doi.org/10.1029/96JD02955>, 1997.
- Kikaj, D., Vaupotič, J., and Chambers, S. D.: Identifying persistent temperature inversion events in a subalpine basin using radon-222, *Atmos. Meas. Tech.*, 12, 4455–4477, <https://doi.org/10.5194/amt-12-4455-2019>, 2019.

- Kikaj, D., Chambers, S. D., Crawford, J., Kobal, M., Gregorič, A., and Vaupotič, J.: Investigating the vertical and spatial extent of radon-based classification of the atmospheric mixing state and impacts on seasonal urban air quality, *Science of The Total Environment*, 872, 162 126, <https://doi.org/10.1016/j.scitotenv.2023.162126>, 2023.
- 915 Lambert, G., Polian, G., Taupin, D., Jbullet, G., and Lambert, R.: Existence of periodicity in radon concentrations and in the large-scale circulation at lower altitudes' between 40 ø and 70 ø South, *J. Geophys. Res.*, 75, 2341–2345, <https://doi.org/10.1029/JC075i012p02341>, 1970.
- Levin, I.: Atmospheric CO₂ in continental Europe—an alternative approach to clean air CO₂ data, *Tellus B*, 39B, 21–28, <https://doi.org/10.1111/j.1600-0889.1987.tb00267.x>, 1987.
- 920 Levin, I., Born, M., Cuntz, M., Langendörfer, U., Mantsch, S., Naegler, T., Schmidt, M., Varlagin, A., Verclas, S., and Wagenbach, D.: Observations of atmospheric variability and soil exhalation rate of radon-222 at a Russian forest site. Technical approach and deployment for boundary layer studies, *Tellus B*, 54, 462–475, <https://doi.org/10.1034/j.1600-0889.2002.01346.x>, 2002.
- Levin, I., Karstens, U., Hammer, S., DellaColetta, J., Maier, F., and Gachkivskyi, M.: Limitations of the radon tracer method (RTM) to estimate regional greenhouse gas (GHG) emissions – a case study for methane in Heidelberg, *Atmos. Chem. Phys.*, 21, 17 907–17 926, <https://doi.org/10.5194/acp-21-17907-2021>, 2021.
- 925 Liu, J., Fung, I., Kalnay, E., and Kang, J.-S.: CO₂ transport uncertainties from the uncertainties in meteorological fields, *Geophysical Research Letters*, 38, <https://doi.org/10.1029/2011GL047213>, _eprint: <https://onlinelibrary.wiley.com/doi/pdf/10.1029/2011GL047213>, 2011.
- 930 Lunt, M. F., Manning, A. J., Allen, G., Arnold, T., Bauguitte, S. J.-B., Boesch, H., Ganesan, A. L., Grant, A., Helfter, C., Nemitz, E., O'Doherty, S. J., Palmer, P. I., Pitt, J. R., Rennick, C., Say, D., Stanley, K. M., Stavert, A. R., Young, D., and Rigby, M.: Atmospheric observations consistent with reported decline in the UK's methane emissions (2013–2020), *Atmos. Chem. Phys.*, 21, 16 257–16 276, <https://doi.org/10.5194/acp-21-16257-2021>, 2021.
- Mahowald, N. M., Rasch, P. J., and Prinn, R. G.: Cumulus parameterizations in chemical transport models, *Geophys. Res. Atmos.*, 100, 26 173–26 189, <https://doi.org/10.1029/95JD02606>, 1995.
- 935 Manning, A. J., O'Doherty, S., Jones, A. R., Simmonds, P. G., and Derwent, R. G.: Estimating UK methane and nitrous oxide emissions from 1990 to 2007 using an inversion modeling approach, *Geophys. Res. Atmos.*, 116, <https://doi.org/10.1029/2010JD014763>, 2011.
- Manning, A. J., Redington, A. L., Say, D., O'Doherty, S., Young, D., Simmonds, P. G., Vollmer, M. K., Mühle, J., Arduini, J., Spain, G., Wisher, A., Maione, M., Schuck, T. J., Stanley, K., Reimann, S., Engel, A., Krummel, P. B., Fraser, P. J., Harth, C. M., Salameh, P. K., Weiss, R. F., Gluckman, R., Brown, P. N., Watterson, J. D., and Arnold, T.: Evidence of a recent decline in UK emissions of hydrofluorocarbons determined by the InTEM inverse model and atmospheric measurements, *Atmos. Chem. Phys.*, 21, 12 739–12 755, <https://doi.org/10.5194/acp-21-12739-2021>, 2021.
- 940 Munassar, S., Monteil, G., Scholze, M., Karstens, U., Rödenbeck, C., Koch, F.-T., Totsche, K. U., and Gerbig, C.: Why do inverse models disagree? A case study with two European CO₂ inversions, *Atmospheric Chemistry and Physics*, 23, 2813–2828, <https://doi.org/10.5194/acp-23-2813-2023>, publisher: Copernicus GmbH, 2023.
- 945 Nisbet, E. and Weiss, R.: Top-Down Versus Bottom-Up, *Science*, 328, 1241–1243, <https://doi.org/10.1126/science.1189936>, 2010.
- Penkett, S. A., Plane, J. M. C., Comes, F. J., Clemitshaw, K. C., and Coe, H.: The Weybourne Atmospheric Observatory, *J. Atmos. Chem.*, 33, 107–110, <https://doi.org/10.1023/A:1026428102821>, 1999.
- Pereira, E. B. and Da Silva, H. E.: Atmospheric radon measurements by electrostatic precipitation, *Nucl. Instrum. Methods Phys. Res. A*, 280, 503–505, [https://doi.org/10.1016/0168-9002\(89\)90960-1](https://doi.org/10.1016/0168-9002(89)90960-1), 1989.
- 950

- Perrino, C., Pietrodangelo, A., and Febo, A.: An atmospheric stability index based on radon progeny measurements for the evaluation of primary urban pollution, *Atmospheric Environment*, 35, 5235–5244, [https://doi.org/10.1016/S1352-2310\(01\)00349-1](https://doi.org/10.1016/S1352-2310(01)00349-1), 2001.
- Polian, G., Lambert, G., Ardouin, B., and Jegou, A.: Long-range transport of continental radon in subantarctic and antarctic areas, *Tellus B: Chem. Phys. Meteorol.*, 38, 178–189, <https://doi.org/10.3402/tellusb.v38i3-4.15126>, 1986.
- 955 Röttger, S., Röttger, A., Mertes, F., Morosch, V., Ballé, T., and Chambers, S.: Evolution of traceable radon emanation sources from MBq to few Bq, *Appl. Radiat. Isot.*, 196, 110726, <https://doi.org/10.1016/j.apradiso.2023.110726>, 2023.
- Schmithüsen, D., Chambers, S., Fischer, B., Gilge, S., Hatakka, J., Kazan, V., Neubert, R., Paatero, J., Ramonet, M., Schlosser, C., Schmid, S., Vermeulen, A., and Levin, I.: A European-wide ²²²Rn and ²²²Rn progeny comparison study, *Atmos. Meas. Tech.*, 10, 1299–1312, <https://doi.org/10.5194/amt-10-1299-2017>, 2017.
- 960 Stanley, K. M., Grant, A., O’Doherty, S., Young, D., Manning, A. J., Stavert, A. R., Spain, T. G., Salameh, P. K., Harth, C. M., Simmonds, P. G., Sturges, W. T., Oram, D. E., and Derwent, R. G.: Greenhouse gas measurements from a UK network of tall towers: technical description and first results, *Atmos. Meas. Tech.*, 11, 1437–1458, <https://doi.org/10.5194/amt-11-1437-2018>, 2018.
- Stavert, A. R., O’Doherty, S., Stanley, K., Young, D., Manning, A. J., Lunt, M. F., Rennick, C., and Arnold, T.: UK greenhouse gas measurements at two new tall towers for aiding emissions verification, *Atmos. Meas. Tech.*, 12, 4495–4518, [https://doi.org/10.5194/amt-12-4495-](https://doi.org/10.5194/amt-12-4495-2019)
965 2019, 2019.
- Stull, R. B.: An introduction to boundary layer meteorology, <https://doi.org/10.1007/978-94-009-3027-8>, publication Title: An introduction to boundary layer meteorology ADS Bibcode: 1988aitb.book.....S, 1988.
- Taguchi, S., Iida, T., and Moriizumi, J.: Evaluation of the atmospheric transport model NIRE-CTM-96 by using measured radon-222 concentrations, *Tellus B: Chem. Phys. Meteorol.*, 54, 250–268, <https://doi.org/10.3402/tellusb.v54i3.16664>, 2002.
- 970 Taylor, J. A. and Lucas, J.: Atmospheric radon monitor., Tech. Rep. ANL-7220, Argonne National Lab., Ill., <https://www.osti.gov/biblio/4405995>, 1967.
- Thomas, J. W. and Leclare, P. C.: A study of the two-filter method for radon-222, *Health Phys.*, 18, 113, https://journals.lww.com/health-physics/Abstract/1970/02000/A_Study_of_the_Two_filter_Method_for_Radon_222.2.aspx, 1970.
- Tolk, L. F., Meesters, A. G. C. A., Dolman, A. J., and Peters, W.: Modelling representation errors of atmospheric CO₂ mixing ratios at a
975 regional scale, *Atmos. Chem. Phys.*, 8, 6587–6596, <https://doi.org/10.5194/acp-8-6587-2008>, 2008.
- van der Laan, S., Neubert, R. E. M., and Meijer, H. a. J.: Methane and nitrous oxide emissions in The Netherlands: ambient measurements support the national inventories, *Atmos. Chem. Phys.*, 9, 9369–9379, <https://doi.org/10.5194/acp-9-9369-2009>, 2009.
- van der Laan, S., van der Laan-Luijkx, I. T., Zimmermann, L., Conen, F., and Leuenberger, M.: Net CO₂ surface emissions at Bern, Switzerland inferred from ambient observations of CO₂, δ(O₂/N₂), and ²²²Rn using a customized radon tracer inversion, *Geophys. Res. Atmos.*,
980 119, 1580–1591, <https://doi.org/10.1002/2013JD020307>, 2014.
- Vogel, F., Ishizawa, M., Chan, E., Chan, D., Hammer, S., Levin, I., and Worthy, D.: Regional non-CO₂ greenhouse gas fluxes inferred from atmospheric measurements in Ontario, Canada, *Journal of Integrative Environmental Sciences*, 9, 41–55, <https://doi.org/10.1080/1943815X.2012.691884>, publisher: Taylor & Francis _eprint: <https://doi.org/10.1080/1943815X.2012.691884>, 2012.
- 985 Wada, A., Matsueda, H., Murayama, S., Taguchi, S., Hirao, S., Yamazawa, H., Moriizumi, J., Tsuboi, K., Niwa, Y., and Sawa, Y.: Quantification of emission estimates of CO₂, CH₄ and CO for East Asia derived from atmospheric radon-222 measurements over the western North Pacific, *Tellus B: Chem. Phys. Meteorol.*, 65, 18037, <https://doi.org/10.3402/tellusb.v65i0.18037>, 2013.

- Whittlestone, S. and Zahorowski, W.: Baseline radon detectors for shipboard use: Development and deployment in the First Aerosol Characterization Experiment (ACE 1), *Geophys. Res. Atmos.*, 103, 16 743–16 751, <https://doi.org/10.1029/98JD00687>, 1998.
- 990 Wigand, A. and Wenk, F.: Der gehalt der luft an radium-emanation, nach messungen bei flugzeugaufstiegen, *Ann. Phys.*, 391, 657–686, <https://doi.org/10.1002/andp.19283911302>, 1928.
- Williams, A. G., Chambers, S., and Griffiths, A.: Bulk mixing and decoupling of the nocturnal stable boundary layer characterized using a ubiquitous natural tracer, *Boundary-Layer Meteorol.*, 149, 381–402, <https://doi.org/10.1007/s10546-013-9849-3>, 2013.
- Williams, A. G., Chambers, S. D., Conen, F., Reimann, S., Hill, M., Griffiths, A. D., and Crawford, J.: Radon as a tracer of atmospheric influences on traffic-related air pollution in a small inland city, *Tellus B: Chemical and Physical Meteorology*, 68, 995 <https://doi.org/10.3402/tellusb.v68.30967>, 2016.
- Wright, A. G.: PMT background, in: *The Photomultiplier Handbook*, edited by Wright, A. G., p. 0, Oxford University Press, <https://doi.org/10.1093/oso/9780199565092.003.0006>, 2017.
- Wright, J. R. and Smith, O. F.: The variation with meteorological conditions of the amount of radium emanation in the atmosphere, in the soil gas, and in the air exhaled from the surface of the ground, at Manila, *Phys. Rev.*, 5, 459–482, <https://doi.org/10.1103/PhysRev.5.459>, 1000 1915.
- Xia, Y., Sartorius, H., Schlosser, C., Stöhlker, U., Conen, F., and Zahorowski, W.: Comparison of one- and two-filter detectors for atmospheric ²²²Rn measurements under various meteorological conditions, *Atmos. Meas. Tech.*, 3, 723–731, <https://doi.org/10.5194/amt-3-723-2010>, 2010.
- 1005 Yver Kwok, C., Laurent, O., Guemri, A., Philippon, C., Wastine, B., Rella, C. W., Vuillemin, C., Truong, F., Delmotte, M., Kazan, V., Darding, M., Lebègue, B., Kaiser, C., Xueref-Rémy, I., and Ramonet, M.: Comprehensive laboratory and field testing of cavity ring-down spectroscopy analyzers measuring H₂O, CO₂, CH₄ and CO, *Atmos. Meas. Tech.*, 8, 3867–3892, <https://doi.org/10.5194/amt-8-3867-2015>, 2015.
- Yver-Kwok, C., Philippon, C., Bergamaschi, P., Biermann, T., Calzolari, F., Chen, H., Conil, S., Cristofanelli, P., Delmotte, M., Hatakka, 1010 J., Heliasz, M., Hermansen, O., Komínková, K., Kubistin, D., Kumps, N., Laurent, O., Laurila, T., Lehner, I., Levula, J., Lindauer, M., Lopez, M., Mammarella, I., Manca, G., Marklund, P., Metzger, J.-M., Mölder, M., Platt, S. M., Ramonet, M., Rivier, L., Scheeren, B., Sha, M. K., Smith, P., Steinbacher, M., Vítková, G., and Wyss, S.: Evaluation and optimization of ICOS atmosphere station data as part of the labeling process, *Atmos. Meas. Tech.*, 14, 89–116, <https://doi.org/10.5194/amt-14-89-2021>, 2021.
- Zahorowski, W., Chambers, S. D., and Henderson-Sellers, A.: Determination of mid-latitude radon-222 flux from the Southern Ocean using atmospheric radon-222 concentration measurements at an island ground station, https://inis.iaea.org/collection/NCLCollectionStore/_Public/36/003/36003223.pdf?r=1#page=5&zoom=auto,-15,800, publisher: International Atomic Energy Agency, 2004.
- Zhang, B., Liu, H., Crawford, J. H., Chen, G., Fairlie, T. D., Chambers, S., Kang, C.-H., Williams, A. G., Zhang, K., Considine, D. B., Sulprizio, M. P., and Yantosca, R. M.: Simulation of radon-222 with the GEOS-Chem global model: emissions, seasonality, and convective transport, *Atmos. Chem. Phys.*, 21, 1861–1887, <https://doi.org/10.5194/acp-21-1861-2021>, 2021.